



FEE PAID AND SENT WITH ONE

**APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT**

Portland, Maine, April 11, 1951

PERMIT ISSUED

00574

APR 13 1951

CITY OF PORTLAND

H-A-T-H

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Lot 57 Raymond Road Use of Building-1-family dwelling No. Stories

New
Main Building
Permitting

Name and address of owner of appliance Placid Violette, 191 Grant Street

Telephone 2-2115

Installer's name and address Other

General Description of Work

To install oil burning equipment and forced hot water heating system

IF HEATER, OR POWER BOILER

Location of appliance or source of heat	basement	Type of floor beneath appliance	concrete
If wood, how protected?		Kind of fuel	oil
Minimum distance to wood or combustible material, from top of appliance or casing top of furnace	27"		
From top of smoke pipe	21"	From front of appliance over 4'	over 3'
Size of chimney flue	8x12	Other connections to same flue	none
If gas fired, how vented?		Rated maximum demand per hour	

IF OIL BURNER

Name and type of burner	American Standard	Labeled by underwriters' laboratories?	yes
Will operator be always in attendance?		Does oil supply line feed from top or bottom of tank?	bottom
Type of floor beneath burner	concrete	Number and capacity of tanks	1-275 gal.
Location of oil storage	basement		
If two 275-gallon tanks, will three-way valve be provided?			
Will all tanks be more than five feet from any base?	yes	How many tanks are needed?	
Total capacity of any existing storage tanks for furnace barrels	none		

IF COOKING APPLIANCE

Location of appliance	Kind of fuel	Type of floor beneath appliance
If wood, how protected?		
Minimum distance to wood or combustible material from top of appliance		
From front of appliance	From sides and back	From top of smoke pipe
Size of chimney flue	Other connections to same flue	
Is hood to be provided?	If so, how vented?	
If gas fired, how vented?		Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? \$2.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

4-11-51 A.M.

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of Installer

Placid Violette

INSPECTION COPY