

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph F. Gray Jr.
Director

CITY OF PORTLAND

JUNE 30, 1997

CLARK GUY L
1295 FOREST AVE
PORTLAND ME 04103

Re: 1295 FOREST AVE
CBL: 202- - A-005-001-Q1
DU:

Dear Mr. Clark:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above-referred property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:

1. INT - OVERALL - 113.50
HARD-WIRED BATTERY-BACK/UP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT
- PERMIT BY MASTER ELECTRICIAN

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you

Sincerely,

Kevin Carroll
Kevin Carroll
Code Enforcement Officer

Tammy Munson
Tammy Munson
Code Enfc. Offc./ Field Supv.

Inspection Services
Samuel P. Hoffses
Chief



CITY OF PORTLAND

Planning and Urban Development
Joseph E. Gray Jr.
Director

March 03, 1994

CLARK GUY L
1295 FOREST AVE
PORTLAND ME 04103

Re: 1295 Forest Ave
C3L: 292- - A-005-001-01
DU: 3

Dear Mr. Clark,

I am sending you this letter to request an inspection at the property which you own or manage at the above referenced address.

This is for the City of Portland's program to inspect all multi-family buildings in the City every three years.

Please contact me in this office at 874-8300 X8709 between 8:00-9:00AM or 4:00-5:00PM to make arrangements to inspect the building.

Sincerely,


David Jordan
Code Enforcement Officer