

## Request for Clarification of Information

Address: 44 Maggie Lane

Permit #: 2016-02272

Date: 10/17/2016

Reviewer: Greg Gilbert

1. Show the location of the Drainage pipes at the foundation - *AROUND EXISTING OF FULL FOUNDATION. INSTALLING NEW PIPES AROUND 4' FROST WALL FOR DIFFICULT + NO PURPOSE.*
2. Will the crawl space be filled back up to grade or left open down to the footing as shown in the drawing? *FILLED TO GRADE.*
3. What are the sizes of on the crawl space vents as shown on the drawing? *NONE.*
4. Specify the size and spacing of the anchor bolts *1/2" BOLTS - 24" O.C.*
5. Call out the header sizes for the new windows *3-2x8 KD spruce w/ plywood.*
6. Call out full dimension of windows in addition. *@ unit R.O. IS. 3'-2 1/8" x 4'-8 7/8" H. MULLION = 6'-4" W x 4'-8 7/8" H. (6'-3 3/16" x 4'-9 1/4" IN 200 SERIES - ANDERSON)*
7. Will there be windows on the sides of the additions? *NO.*
8. Specify the species of wood being used for the floor joist and roof rafters *KD. SPURCE.*
9. Specify the grade of insulation *F.G. AND RIGID FOAM, 2x6 STUDS. R-25 IN FLOOR. R 49 IN ROOF - R 23 MIN. IN WALLS - 6" F.G. + 1" RIGID FOAM*
10. Where would roof end up if you changed the slope to 3:12 - *IT WOULD BE TOO HIGH - WE HAVE EXISTING WINDOWS ABOVE, AND NEED SPACE FOR FLASHING.*
11. How will the new roof rafters be connected to the existing house? *A 2x8 LEDGER WILL BE LAG SCREWED IN STUDS - 16" O.C (EXISTING WALL)*
12. Specify new framing in fill of existing bay windows. *2x6 KD spruce, 16 O.C, 1/2" CDX, tyvek, vinyl - 1/2" sheetrock interior.*
13. What type of sheathing is being used in the new exterior walls?

*1/2" CDX - 5 ply.*

*Designer:*

*Wendy Stanley  
70 Roberts Street  
Portland, Maine 04102  
(207) 899-2530*

*Builder - Steve Duteau  
175 S. Forest  
865-4412*