

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



This is to certify that

BENTLEY HOLDINGS INC

Located at

55 WARREN AVE

PERMIT ID: 2014-02754

ISSUE DATE: 02/03/2015

CBL: 292 D006001

has permission to **Change of use from fitness Center to retail - Interior renovations, 2' canopy on two sides of the existing building**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

Fire Official

/s/ Jeanie Bourke

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Retail

***Building Inspections***

Use Group: M/S-1/H- Type: 2B,  
2 Greenh  
ouse 5B

Mercantile - retail garden center  
Storage - Ordinary & Hazardous  
NFPA 13 System  
Storage - Greenhouse

ENTIRE

MUBEC/IBC 2009

***Fire Department***

Classification:

Class B Mercantile  
ENTIRE

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Site VISIT

Final - DRC

Pre-Construction Meeting

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Above Ceiling Inspection

Certificate of Occupancy/Final

Final - Electric

Fire - Change of Use Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2014-02754	<b>Date Applied For:</b> 11/25/2014	<b>CBL:</b> 292 D006001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Paris Farmers Union - Retail Garden Center	<b>Proposed Project Description:</b> Change of use from fitness Center to retail - Interior renovations, 2 canopy on two sides of the existing building			
<p><b>Dept:</b> Zoning      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> Ann Machado      <b>Approval Date:</b> 12/09/2014</p> <p><b>Note:</b> Marge had signed off on the site plan except for having the 30' delineation of the B-4 extension into the R-5 zone be shown on the site plan. This 30' is delineated on the current site plan.      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</li> <li>2) Separate permits shall be required for any new signage.</li> </ol>				
<p><b>Dept:</b> Building      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> Jeanie Bourke      <b>Approval Date:</b> 02/02/2015</p> <p><b>Note:</b>      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) The 18'x64' greenhouse is not approved as per noted on the site plans.</li> <li>2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.</li> <li>3) This approves a reduction in the plumbing fixture count based upon the actual design occupant load per IBC Sec. 1004.1.1 per information provided.</li> <li>4) Penetrations through fire resistance rated assemblies shall be protected by an approved penetration firestop system installed as tested in accordance with ASTM E814 or UL 1479</li> <li>5) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.</li> </ol>				
<p><b>Dept:</b> Fire      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> David Petruccelli      <b>Approval Date:</b> 12/12/2014</p> <p><b>Note:</b>      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) Fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions or any other wall required to have protected openings or penetrations shall be effectively and permanently identified with signs or stenciling in accessible concealed floor, floor-ceiling or attic spaces at intervals not exceeding 30 feet with lettering not less than 0.5 inches in height.</li> <li>2) Construction or installation shall comply with City Code Chapter 10.</li> <li>3) Application requires State Fire Marshal approval.</li> <li>4) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer. .</li> <li>5) A separate Fire Alarm Permit is required for new systems; or for work affecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.</li> <li>6) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.</li> <li>7) Fire department connection type and location shall be approved in writing by Fire Prevention Bureau.</li> <li>8) A firefighter Building Marking Sign is required.</li> <li>9) Fire extinguishers are required per NFPA 1.</li> <li>10 All means of egress to remain accessible at all times.</li> </ol>				

**PERMIT ID:** 2014-02754

**Located at:** 55 WARREN AVE

**CBL:** 292 D006001

- 11 Any cutting and welding done will require a Hot Work Permit from Fire Department.
- 12 Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.
- 13 Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.
- 14 \*\*The fire alarm system design shall be evaluated for the renovated areas by an NICET IV certified interior fire alarm designer or a licensed engineer for compliance with the code. A compliance letter is required prior to the final inspection.\*\*  
\*\*A current inspection sticker from an approved fire alarm inspection company is required prior to the final inspection.\*\*
- 15 The approved plans with the Building Department Approved stamp shall be maintained on site for inspection.
- 16 Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.

**Dept:** DRC      **Status:** Approved w/Conditions      **Reviewer:** Philip DiPierro      **Approval Date:** 01/08/2015

**Note:**      **Ok to Issue:**

**Conditions:**

- 1) See approval letter dated 11-14-14, Planning Authority approval dated 11-14-14, for conditions of approval.