

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

EVOLUTION PORTLAND PROPERTIES LLC/Northeast
Security Systems

Located at

65 WARREN AVE

PERMIT ID: 2014-02171

ISSUE DATE: 09/25/2014

CBL: 292 D014001

has permission to **For the installation of a Fire Alarm System for "Evolution Rocks" - an indoor rock climbing and fitness gym.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

health club/gymnasium use group -
Evolution Rock & fitness

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-02171	Date Applied For: 09/17/2014	CBL: 292 D014001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Health Club/ Gymnasium		Proposed Project Description: For the installation of a Fire Alarm System for "Evolution Rocks" - an indoor rock climbing and fitness gym.		
Dept: Zoning Status: Approved		Reviewer: Marge Schmuckal	Approval Date: 09/22/2014	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
Dept: Fire Status: Approved w/Conditions		Reviewer: Craig Messinger	Approval Date: 09/25/2014	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) The fire alarm system shall have a new fire alarm inspection sticker. 2) System acceptance and commissioning must be coordinated with a fire alarm technician and suppression system contractors and the Fire Department. Call 874-8400 to schedule. 3) Records cabinet, FACP, annunciator(s), and pull stations shall be keyed alike. 4) Shall meet the requirements of NFPA 72, National Fire Alarm and Signaling Code. 5) Shall meet the requirements of 2009 NFPA 1 Fire Code.				