Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 09/25/14

MP MANUAL PULL STATION

HS HORN/STROBE

STROBE

S SMOKE DETECTOR

LIFE SAFETY NOTES:
1. DIAGONAL = 145'-1", THEREFORE 2ND MEANS OF EGRESS MUST BE 72'-7"
EXIT SEPARATION: 112'

FOR CONSTRUCTION

HILARY HARRIS, AIA
LEED AP
PO BOX 22
CONCORD, NH 03302
PH: (603) 496-1239
EMAIL:
hilaryharris@gmail.com

EVO ROCK & FITNESS
PORTLAND, ME

ISSUE

DATE	BY	REMARKS
01JUL13	HBH	PLANNING BOARD REVIEW
09APR14	HBH	FOR CONSTRUCTION

DRAWING TITLE:
1ST FLOOR PLAN

STAMP:

SCALE: 1/8"=1'-0"

DSN TEAM:

SHEET NUMBER:
A-1.1