Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 03/10/14

1 A.4 ELECTRICAL & LIFE SAFETY PLAN

SCALE: 1/4" = 1'-0"

PROJECT DATA

EXISTING THREE STORY BUILDING CONSTRUCTED IN 1988 (BOCA 1986)
THIRD FLOOR: 14,800 SF
TOTAL BUILDING: 40,360 SF

BUILDING OCCUPANCY : BUSINESS OFFICES

OCCUPANCY GROUP: IBC: B, BUSINESS
NFPA: EXISTING BUSINESS

CONSTRUCTION TYPE: IBC: TYPE II B
NFPA: TYPE II 000

CLIMATE ZONE: 6A

AUTOMATIC FIRE SPRINKLER: YES

FIRE ALARM SYSTEM: YES, MONITORED

ELECTRICAL AND LIFE SAFETY DEVICE LEGEND

- DUPLEX OUTLET 18" A.F.F. UNLESS NOTED OTHERWISE PROVIDE GFI @ TOILET ROOMS & AREAS WITH SINKS
- DUPLEX OUTLET ABOVE COUNTER TOP - 44" AFF PROVIDE GFI @ TOILET ROOMS & AREAS WITH SINKS
- DOUBLE DUPLEX OUTLET 18" A.F.F. UNLESS NOTED OTHERWISE "C" INDICATES COUNTER HEIGHT "GFI" INDICATES GROUND FAULT
- SINGLE POWER OUTLET
- COMBINATION PHONE AND DATA OUTLET 18" A.F.F. UNLESS NOTED OTHERWISE "C" INDICATES COUNTER HEIGHT
- EXIT SIGN WITH ARROWS AS INDICATED - CEILING MOUNTED
- EXIT SIGN WITH ARROWS AS INDICATED - WALL MOUNTED
- EXISTING EXIT SIGN
- TWIN HEAD EMERGENCY LIGHT - 4 AVAILABLE FOR REUSE
- EXISTING TWIN HEAD EMERGENCY LIGHT
- S 15 FIRE ALARM SYSTEM-STROBE LIGHT (#=CANDELLA)
- F 15 FIRE ALARM SYSTEM-HORN/STROBE LIGHT (#=CANDELLA)
- F EXISTING FIRE ALARM SYSTEM-HORN/STROBE LIGHT
- F FIRE ALARM MANUAL PULL
- F EXISTING FIRE ALARM MANUAL PULL
- FE FIRE EXTINGUISHER IN CABINET
- FE FIRE EXTINGUISHER - NO CABINET
- FE FIRE EXTINGUISHER - NO CABINET
- ELECTRICAL PANEL
- SWITCHES

2 A.4 KEY PLAN - THIRD FLOOR

SCALE: 1/16" = 1'-0"

MMP OTOLARYNGOLOGY

1250 FOREST AVENUE PORTLAND, MAINE

LICENSED ARCHITECT ANNE E. CALLENDER No. 1861 STATE OF MAINE

WHIPPLE — CALLENDER ARCHITECTS

136 PLEASANT AVE.
PORTLAND, ME 04103
P 207.775.2696
F 207.775.3631
www.whipplecallender.com

MARK	DATE	DESCRIPTION
	1-21-13	PERMIT SET
	1-30-13	REVISIONS TO PLAN
1	1-27-14	REVISIONS TO PLAN; UPDATE FOR PERMIT
2	2-25-14	REVISIONS TO DOCTOR'S OFFICE 108
3	3-7-14	ADDITION OF KEY PLAN & PROJECT DATA

DATE: 21 JAN 2013

CHECKED BY: AEC

DRAWN BY: AEC

JOB: 12-TFA

SHEET TITLE: ELECTRICAL AND LIFE SAFETY PLAN

FIRST FLOOR OFFICE PLAN

A.4

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND SHALL REMAIN THE PROPERTY OF WHIPPLE CALLENDER ARCHITECTS. IT SHALL NOT BE USED FOR ANY OTHER PURPOSE THAT FOR WHICH IT IS SPECIFICALLY FURNISHED