

Inspection Services
Michael J. Nugent
Manager

Department of Urban Development
Joseph E. Gray, Jr.
Director



CITY OF PORTLAND
STOP WORK NOTICE

November 29, 2000

Custom Built Homes of Maine/Glen Gervais
27 Main Street
Windham, Maine 04062

RE: Lot 5 Maggie Lane
CBL: 292-G-005

HAND DELIVER

Dear Mr. Gervais:

An evaluation of the property at Lot 5 on Maggie Lane revealed that the structure fails to comply with Section 107.1 of the Building Code of the City of Portland;

1. Placing concrete without and inspection

This is a **STOP WORK ORDER** pursuant to Section 117.1 of the Building Code (1996 BOCA). All construction activity must Stop immediately.

Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code and in Title 30-A M.R.S.A. Ss 4452. This constitutes an appealable decision pursuant to Section 121.5 of the Code. Please feel free to contact me at 874-8709, if you wish to discuss the matter or have any questions.

Sincerely,

Stephen Wentworth
Code Enforcement Officer

Cc: Central File
Joseph Gray