

Inspection Services
Michael J. Nugent
Manager

Department of Urban Development
Joseph E. Gray, Jr.
Director



CITY OF PORTLAND

October 10, 2000

Alexander N Rozman
100 Bower St
Nashua, NH 03060

RE: 1320 Forest Ave
CBL: 292-D-003

Dear Mr. Rozman:

Certified Mail Receipt # 7099 3400 0019 5716 3121

An evaluation of your property at 1320 Forest Ave. on October 3, 2000 revealed that the subsurface waste disposal system at the above location is malfunctioning. This is a violation of Section 100.7 of the State Plumbing Code. Attached is a list copy of the referenced Code section.

This is a notice of violation pursuant to Section 113.2 of the Code. It is required that you connect to the municipal sewer system. This activity must occur within 30 days. A reinspection of the premises will occur on November 13, 2000 at which time compliance will be required. Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code and in Title 30-A M.R.S.A. ss 4452.

Please feel free to contact me at 874-8697, if you wish to discuss the matter or have any questions.

Sincerely

Arthur Rowe
Code Enforcement Officer

Dc/ar