



924400

FILL IN AND SIGN WITH INK

PERMIT ISSI

DEC - 9 1992

CITY OF PORTLAND

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, 12/8/292

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 30 Warren /Ave Use of Building office/storages Stories New Building
 Name and address of owner of appliance Salvation Army, 297 Cumberland A-Pt1d Existing
 Installer's name and address Mechanical Services Inc 400 Presumpscot S Rtx- Pt1d, ME 04103 Telephone 774-1531
 General Description of Work
 To install replacement oil burner

IF HEATER, OR POWER BOILER

Location of appliance Any burnable material in floor surface or beneath? Kind of fuel?
 If so, how protected?
 Minimum distance to burnable material, from top of appliance or casing top of furnace
 From top of smoke pipe From front of appliance From sides or back of appliance
 Size of chimney flue Other connections to same flue
 If gas fired, how vented? Rated maximum demand per hour
 Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner Webster Labelled by underwriters' laboratories? YES
 Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? top
 Type of floor beneath burner concrete Size of vent pipe 2 inch
 Location of oil storage underground Number and capacity of tanks one 10,000 gal
 Low water shut off yes Make McDonald Miller No. 51-2
 Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
 Total capacity of any existing storage tanks for furnace burners 10,000

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
 If so, how protected? Height of Legs, if any
 Skirting at bottom of appliance? Distance to combustible material from top of appliance?
 From front of appliance From sides and back From top of smokepipe
 Size of chimney flue Other connections to same flue
 Is hood to be provided? If so, how vented? Forced or gravity?
 If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Byron Rogers master oil burner license: ~~None~~ 0.02953
 1. Kind of heat
 2. 1 1/4 VENT PIPE
 3. Burner rigidity & support
 4. Remote control
 5. High limit control
 6. Main cutoff switch
 7. Low water cutoff
 8. High limit control
 9. Piping support & protection
 10. Valves in supply line
 11. Capacity of tanks
 12. Tank rigidity & support
 13. Adequate ventilation
 14. Smokepipe to combustibles
 15. Thermal control switch

APPROVED:

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES

CS 30C
 INSPECTION FILE APPLICANT'S ASSESSOR'S COPY
 Signature of Installer *Byron Rogers*

Mr. Carnell

293-A-001

