

Inside Velux Hood

Second Floor
Ceiling

Duct to go through existing hole in brick

Duct work inside to be wrapped with 3m grease
Duct wrap

24ga galv steel make up air duct

9' Hood

Use 16ga stainless steel grease
Hood. Grease baffle filters,
with make up air piven in front
of Hood

3" air space behind hood

Brick wall outside

Inside wall 5/8 sheet
rock

80"

1" min wood wall face with 24ga
stainless and back with 24ga
galv steel then have 1" air space

Ragpoint Sons LLC
Dan
749-1878

