**Building Inspections - Fwd: Attached Image**

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 09/12/13

**From:** Josh Nappi <josh@imperialph.com>
**To:** <buildinginspections@portlandmaine.gov>
**Date:** 8/5/2013 10:38 AM
**Subject:** Fwd: Attached Image
**Attachments:** 1741_001.pdf; predator.pdf

Dear Sir or Madam,
This permit application is in regards to adding a new and separate cooling system to the kennel room at the Happy Tails dog day care on Bishop St. in Portland. We would like to locate the York rooftop unit behind the building instead
of on the roof because the structure is wood and the unit is 1,050 pounds at operating weight. We would make two penetrations
in the cinderblock rear wall to accommodate the ductwork from the unit. The unit will sit on a steel curb 40 inches off the rear of the
building. This unit will serve as a cooling unit only, there is an existing furnace in operation, the two ductwork systems will be completely
independent of each other. Attached is a pdf of the permit application and drawings of the building as well as a spec sheet on the unit.
I apologize for the files showing up sideways i'm not the greatest with technology.

Thank You,
Josh Nappi

---------- Forwarded message ----------
From: <Store3352@theupsstore.com>
Date: 2013/8/5
Subject: Attached Image
To: josh@imperialph.com

--
Joshua A.Nappi
Imperial Plumbing and Heating
7 Stephenson Street
Cape Elizabeth, ME 04107
207-233-0377
Josh@Imperialph.com