

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

BJG LLC

**Located at**

115 BISHOP ST (#119)

**PERMIT ID:** 2016-02357

**ISSUE DATE:** 09/22/2016

**CBL:** 293 A014001

has permission to **Change of use to add a veterinary clinic and construct three exam rooms.**  
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Michael White*

*/s/ Laurie Leader*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Dog daycare, grooming & training facility and veterinary clinic

***Building Inspections***

**Use Group:** B      **Type:** 3B  
Veteranariy clinic  
Occupant load = 10  
Building is sprinkled  
UNIT #119  
MUBEC/IBC 2009  
MUBEC/IBC 2009

***Fire Department***

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

### **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Final - Electric

Final - Fire

Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2016-02357	<b>Date Applied For:</b> 09/02/2016	<b>CBL:</b> 293 A014001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Dog daycare, grooming & training, plus a veterinary clinic (Brackett St. Vet/VetCor)	<b>Proposed Project Description:</b> Change of use to add a veterinary clinic and construct three exam rooms.			
<p><b>Dept:</b> Zoning      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> Christina Stacey      <b>Approval Date:</b> 09/20/2016</p> <p><b>Note:</b> I-M zone Professional offices including veterinary clinics are an allowed use in this zone per §14-427(t). Vet clinic area is approx. 1,000 sf = 3 parking spaces required - lot has approximately 27 parking spaces.      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only.</li> <li>2) Separate permits shall be required for any new signage.</li> </ol>				
<p><b>Dept:</b> Building Inspecti      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> Laurie Leader      <b>Approval Date:</b> 09/22/2016</p> <p><b>Note:</b>      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) This project includes alterations that Maine state law requires for compliance with the 2010 ADA Standards for Accessible Design.</li> <li>2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.</li> <li>3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.</li> </ol>				
<p><b>Dept:</b> Engineering DPS      <b>Status:</b> Not Applicable      <b>Reviewer:</b> Rachel Smith      <b>Approval Date:</b> 09/07/2016</p> <p><b>Note:</b>      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 207-874-8801</li> </ol>				
<p><b>Dept:</b> Fire      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> Michael White      <b>Approval Date:</b> 09/22/2016</p> <p><b>Note:</b>      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p> <ol style="list-style-type: none"> <li>1) The property owner or occupant shall not make changes in the occupancy, the use or process, or the materials used or stored in the building without evaluation of the fire protection systems for their capability to protect the new occupancy, use, or materials. (2009 NFPA 1, Chapter 13.3.4.1.5).</li> <li>2) A separate Fire Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.</li> <li>3) Means of egress shall be illuminated in accordance with 2009 NPFA 101, Chapter 7.8.</li> <li>4) Portable fire extinguishers shall be installed, inspected and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers. (2009 NFPA 101, Chapter 9.7.4.1).</li> <li>5) All construction shall comply with 2009 NFPA 101, Chapter 39 Existing Business Occupancies.</li> <li>6) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).</li> <li>7) All construction shall comply with City Code, Chapter 10.</li> </ol>				