

Permit No **960939**

Location of Construction: 119 Bishop	Owner: 965 Holdings	Phone:
Owner Address: 701 Commercial St, Ste 250p, Dallas TX 75204	Leasee/Buyer's Name:	Business Name:
Contractor Name: Pollution Control Svcs	Address: P.O. Box 117, Corham 04038	Phone: 892-0864
Past Use: Commercial Bldg	Proposed Use: Same/remove underground tank	COST OF WORK: \$
		PERMIT FEE: \$ 10.00
		FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied
		INSPECTION: Use Group: Type: Signature: <i>[Signature]</i>
Proposed Project Description: Remove 500 gal tank		PEDESTRIAN ACTIVITIES DISTRICT (P.U.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied
Permit Taken By: Vicki Dover	Date Applied For: 9/18/96	Signature: Date:

PERMIT ISSUED
Permit Issued:
SEP 26 1996
CITY OF PORTLAND

Zone: **CBL**
Zoning Approval:
[Signature]
Special Zone or Reviews:
 Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan major minor mm

Zoning Appeal
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:
 Approved
 Approved with Conditions
 Denied
Date: **9/19/96**

[Signature]
CEO DISTRICT #4
A. Lewis

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Approved with letter

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

[Signature]
SIGNATURE OF APPLICANT: **Terrianne McPhillips** ADDRESS: **[Address]** PHONE: **[Phone]**
DATE: **9/18/96**

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE: **White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector** PHONE: **[Phone]**

BUILDING PERMIT REPORT

Date:

9/19/94

Address:

119 Bishop St

Type of Permit:

Owner:

Contractor:

Applicant:

Approved:

Denied:

Conditions:

1. All underground tank removal(s) ~~and/or installation(s)~~ shall be done in accordance with Department of Environmental Protection Regulations (Chapter 691).
2. No cutting of tanks on site. Cutting of tanks to be done at an approved tank disposal site.
3. Fire Dispatcher must be notified 48 hours in advance of removal and/or transportation of tanks.

**NOTICE OF INTENT
TO ABANDON (REMOVE) AN
UNDERGROUND OIL STORAGE FACILITY**

THIS FORM MUST BE FILED WITH THE D.E.P. AND YOUR LOCAL FIRE DEPARTMENT AT LEAST 30 DAYS PRIOR TO THE SCHEDULED REMOVAL

PLEASE TYPE OR PRINT IN INK:

Name of Facility Owner: PRB Holdings C/O The Dunham Group
Mailing Address: 1 Portland Square Telephone #: 207-773-7100
City: Portland State: ME Zip Code: 04101
Contact Person (name, address & telephone #): Greg Hastings C/O The Dunham Group
1 Portland Square Portland, Me. 207-773-7100
Name of Facility: New England Public Whse Registration #: 17930
Facility Location (town & street): 119 Bishop St. Portland

1. Identify the tanks at this location which are going to be removed:

<u>Tank #</u>	<u>Tank Age</u>	<u>Tank Size (gallons)</u>	<u>Type of Product Stored</u>
1	35 yrs.	500	#2 F.O.
2			
3			
4			

2. Directions to this facility (be specific):

3. Is or was the tank(s) used to store Class I liquids (e.g. gasoline, jet fuel)? Yes ___ No ___
IF YES, REMOVAL OF THE TANK(S) MUST BE DONE UNDER THE DIRECTION OF A CERTIFIED TANK INSTALLER.

Tank Installer's Name: Certification Number: Signature:

_____ N/A _____

4. Environmental site assessments are required for all tanks except those used for storing heating oil, not for resale, or for farm or residential motor fuel tanks under 1,100 gallons where the product is used on site. **Site Assessor's Name and Address (if applicable):**

_____ N/A _____

5. Name and telephone number of contractor who will do the tank removal:

Pollution Control Services 207-892-0884

6. Expected date of removal (month/day/year): 9/19/96

I hereby provide Notice that I intend to properly abandon the underground oil storage facility as described above.

PRB Holdings Limited

By: G.P. PRB Holdings, Inc., general partner

Date: 7/25/96

Signature: Clifford A. Booth

Printed Name and Title: Clifford A. Booth
President

**Mail original and yellow copy to DEP; pink copy to fire department; retain gold copy.
RETURN POSTCARD AFTER TANK(S) HAS BEEN REMOVED**

DEPT. OF BUILDING INSPECTION
CITY OF PORTLAND, ME
SEP 18 1996
RECEIVED