

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 04-0092	Issue Date: MAR 25 2004	CBL: 293 A016001
-----------------------	----------------------------	---------------------

Location of Construction: 17 Bishop St	Owner Name: Spurwink School	Owner Address: 899 Riverside St	Phone: CITY OF PORTLAND
Business Name:	Contractor Name: HVAC Services, Inc.	Contractor Address: 73 Bradley Drive Westbrook	Phone: 2078544822
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone: IM

Past Use: School	Proposed Use: Replace Existing Trane/ natural gas heating unit within existing footprint	Permit Fee: \$93.00	Cost of Work: \$7,350.00	CEO District: 5
		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: NA Type: 3/24/04	

Proposed Project Description:  
Replace Existing Trane/ natural gas heating unit within existing footprint.

Signature: *[Signature]* Signature: *[Signature]*

PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)  
Action:  Approved  Approved w/Conditions  Denied  
Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Permit Taken By: Idobson	Date Applied For: 02/02/2004	<b>Zoning Approval</b>
-----------------------------	---------------------------------	------------------------

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..</p>	<p><b>Special Zone or Reviews</b></p> <p><input type="checkbox"/> Shoreland</p> <p><input type="checkbox"/> Wetland</p> <p><input type="checkbox"/> Flood Zone</p> <p><input type="checkbox"/> Subdivision</p> <p><input type="checkbox"/> Site Plan</p> <p>Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/></p> <p>Date: <i>ok 3/23/04</i></p>	<p><b>Zoning Appeal</b></p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Denied</p> <p>Date: _____</p>	<p><b>Historic Preservation</b></p> <p><input checked="" type="checkbox"/> Not in District or Landmark</p> <p><input type="checkbox"/> Does Not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied</p> <p>Date: <i>[Signature]</i></p>
---	--	--	--

**CERTIFICATION**


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT \_\_\_\_\_ ADDRESS \_\_\_\_\_ DATE \_\_\_\_\_ PHONE \_\_\_\_\_



FILL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



04-0092  
293-A-016

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 17 BISHOP ST. Ptld. Use of Building Spurwink Date 3/2/04  
Name and address of owner of appliance Hamstead Assoc. LLC (Dirego Mount)  
One City Center Ptld Me 04101-4009  
Installer's name and address HVAC SERVICES INC Dot 04092  
73 Bradley Drive, WESTBROOK, ME Telephone 207 854 4822

Location of appliance: Direct Replacement - unit -  
 Basement  Floor ABOVE  
 Attic  Roof Ceiling  
Same Footprint  
Type of Fuel:  
 Gas  Oil  Solid  
NATURAL  
Appliance Name: TRANE  
U.L. Approved  Yes  No  
Will appliance be installed in accordance with the manufacture's installation instructions?  Yes  No

Type of Chimney:  
 Masonry Lined  
Factory built \_\_\_\_\_  
 Metal  
Factory Built U.L. Listing # \_\_\_\_\_  
 Direct Vent  
Type PVC UL# SCH 40  
Type of Fuel Tank  
 Oil  
 Gas NATURAL

IF NO Explain: \_\_\_\_\_  
The Type of License of Installer:  
 Master Plumber # \_\_\_\_\_  
 Solid Fuel # \_\_\_\_\_  
 Oil # \_\_\_\_\_  
 Gas # PNT 3734  
 Other \_\_\_\_\_

Size of Tank \_\_\_\_\_  
Number of Tanks \_\_\_\_\_  
Distance from Tank to Center of Flame \_\_\_\_\_ feet.  
Cost of Work: \$ 7,350.00  
Permit Fee: \$ 93.00

Approved  
Fire: \_\_\_\_\_  
Ele.: \_\_\_\_\_  
Bldg.: \_\_\_\_\_

Approved with Conditions  
 See attached letter or requirement  
Inspector's Signature \_\_\_\_\_ Date Approved \_\_\_\_\_

Signature of Installer Wroth & Shumpan

# City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716


Permit No: 04-0092	Date Applied For: 02/02/2004	CBL: 293 A016001
-----------------------	---------------------------------	---------------------

Location of Construction: 17 Bishop St	Owner Name: Spurwink School	Owner Address: 899 Riverside St	Phone:
Business Name:	Contractor Name: HVAC Services, Inc.	Contractor Address: 73 Bradley Drive Westbrook	Phone (207) 854-4822
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: Replace Existing Trane/ natural gas heating unit within existing footprint	Proposed Project Description: Replace Existing Trane/ natural gas heating unit within existing footprint.
---	--

Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 03/23/2004
Note:			Ok to Issue: <input checked="" type="checkbox"/>
Dept: Building	Status: Approved with Conditions	Reviewer: Mike Nugent	Approval Date: 03/24/2004
Note:			Ok to Issue: <input checked="" type="checkbox"/>
1) replacement in exact location, mounting, same or less weight. Must Comply w/ State Gas regs/NFPA regs			
Dept: Fire	Status: Approved	Reviewer: Lt. MacDougal	Approval Date: 03/23/2004
Note:			Ok to Issue: <input checked="" type="checkbox"/>

<b>Comments:</b> 3/18/2004-ldobson: Let message with Dot. Said someone would call in the A. M. Friday 3/2/2004-ldobson: Called 3/1 for additional information - fastener information - unit information - venting specs- 2nd call 3/22/2004-kwd: 3/22/2004: received additional information, forwarded to zoning.
--



Coil weight - 75 lbs  
 Unit weight - 150 lbs  
 Venting - Tied into existing  
 High Efficiency gas Furnace  
 PVC venting

SIDE VIEW (6 1000 POINTS)

JOB 17 BISHOP ST

wood  
 Beams  
 (TYP)

3/8  
 threaded  
 rods (TYP)

3/8  
 Nuts  
 (TYP)

unit

coil