

SECTION 062000 - FINISH CARPENTRY

PART 1 - GENERAL

1.1 SECTION REQUIREMENTS

- A. Submittals: Samples for wood siding.

PART 2 - PRODUCTS

2.1 MATERIALS, GENERAL

- A. Lumber: DOC PS 20 and grading rules of inspection agencies certified by American Lumber Standards Committee Board of Review.
- B. Softwood Plywood: DOC PS 1.

2.2 EXTERIOR FINISH CARPENTRY

- A. Exterior Lumber Trim: Smooth-textured, D select (Quality) eastern white pine, eastern hemlock-balsam fir-tamarack, eastern spruce, or white woods.
 - 1. Maximum Moisture Content: 15 percent.
- B. Lumber Siding: Kiln-dried, Clear VG Heart, western red cedar.

2.3 SHELVING AND CLOTHES RODS

- A. Shelving: Melamine-faced particleboard with radiused and filled front edge.
- B. Shelf Brackets with Rod Support: BHMA A156.16, B04051; prime-painted formed steel.

2.4 MISCELLANEOUS MATERIALS

- A. Fasteners for Exterior Finish Carpentry: hot-dip galvanized steel or aluminum.
- B. Glue: Aliphatic-resin, polyurethane, or resorcinol wood glue recommended by manufacturer.
 - 1. Use waterproof resorcinol glue for exterior applications.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Condition finish carpentry in installation areas for 24 hours before installing.
- B. Prime and backprime lumber for painted finish exposed on the exterior.
- C. Install finish carpentry level, plumb, true, and aligned with adjacent materials. Scribe and cut to fit adjoining work. Refinish and seal cuts.
- D. Install standing and running trim with minimum number of joints practical, using full-length pieces from maximum lengths of lumber available. Stagger joints in adjacent and related trim. Cope at returns and miter at corners.
- E. Nail siding at each stud. Do not allow nails to penetrate more than one thickness of siding, unless otherwise recommended by siding manufacturer. Seal joints at inside and outside corners and at trim locations.

END OF SECTION 062000