

SECTION 102800 - TOILET, BATH, AND LAUNDRY ACCESSORIES

PART 1 - GENERAL

1.1 SECTION REQUIREMENTS

- A. Submittals: Product Data.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Stainless Steel: ASTM A 666, Type 304, No. 4 finish (satin), 0.0312-inch minimum nominal thickness unless otherwise indicated.
- B. Brass: ASTM B 19, ASTM B 16, or ASTM B 30.
- C. Aluminum: ASTM B 221, Alloy 6063-T6 or 6463-T6.
- D. Sheet Steel: ASTM A 1008/A 1008M, 0.0359-inch minimum nominal thickness.
- E. Galvanized-Steel Sheet: ASTM A 653/A 653M, G60.
- F. Chromium Plating: ASTM B 456, Service Condition Number SC 2 (moderate service).
- G. Baked-Enamel Finish: Factory-applied, gloss-white, baked-acrylic-enamel coating.
- H. Tempered Glass: ASTM C 1048, Kind FT (fully tempered).
- I. Mirrors: ASTM C 1503, Mirror Glazing Quality, clear-glass mirrors, nominal 6.0 mm thick.
- J. Galvanized-Steel Mounting Devices: ASTM A 153/A 153M, hot-dip galvanized after fabrication.
- K. Fasteners: Screws, bolts, and other devices of same material as accessory unit, tamper and theft resistant when exposed, and of galvanized steel when concealed.
- L. Keys: Provide universal keys for internal access to accessories for servicing and resupplying. Provide minimum of six keys to Owner's representative.

2.2 TOILET AND BATH ACCESSORIES

- A. Manufacturers:
 - 1. Bradley or Bobrick.

- B. Paper Towel Dispenser PT:
 - 1. Install salvaged combination dispenser / waste unit from existing toilet room.
- C. Toilet Tissue Dispenser TP:
 - 1. Basis-of-Design Product: Bradley 505.
- D. Liquid-Soap Dispenser SD:
 - 1. Install salvaged dispenser from existing toilet room.
- E. Soap Dish SD1:
 - 1. Basis-of-Design Product: Bradley 900.
- F. Grab Bar GB:
 - 1. Basis-of-Design Product: Bradley 8120-00136 and 8120-00142.
- G. Mirror M1:
 - 1. Basis-of-Design Product: Bradley 780-1836
- H. Shower Curtain Rod:
 - 1. Basis-of-Design Product: Bradley 9532.
- I. Shower Curtain:
 - 1. Basis-of-Design Product: Bradley 9537.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install accessories using fasteners appropriate to substrate indicated and recommended by unit manufacturer. Install units level, plumb, and firmly anchored in locations and at heights indicated.
 - 1. Install grab bars to withstand a downward load of at least 250 lbf, when tested according to method in ASTM F 446.
- B. Adjust accessories for unencumbered, smooth operation and verify that mechanisms function properly. Replace damaged or defective items. Remove temporary labels and protective coatings.

END OF SECTION 102800