

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT

**This is to certify that**

AVESTA BISHOP STREET LP

**Located at**

78 BISHOP ST (72 Bishop St)

**PERMIT ID:** 2016-02650

**ISSUE DATE:** 11/30/2016

**CBL:** 293 C002001

has permission to **For the installation of a Water-Based Fire Suppression System for "Avesta Housing" - Three (3) Floors (21,375 SF).**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Michael White*

*/s/ Michael Russell, MS, Director*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*

*Building Inspections*

*Fire Department*

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

## **REQUIRED INSPECTIONS:**

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

|   |  |  |  |                                  |
|---|--|--|--|----------------------------------|
| <b>City of Portland, Maine - Building or Use Permit</b>   |  | <b>Permit No:</b><br>2016-02650  | <b>Date Applied For:</b><br>10/07/2016 | <b>CBL:</b><br>293 C002001       |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716   |  |  |  |                                  |
| <b>Proposed Use:</b><br>Same: 30-efficiency residential units with support services ("Avesta Housing")  |  | <b>Proposed Project Description:</b><br>For the installation of a Water-Based Fire Suppression System for "Avesta Housing" - Three (3) Floors (21,375 SF). |  |                                  |
| <b>Dept:</b> Zoning   |  | <b>Status:</b> Approved w/Conditions   | <b>Reviewer:</b> Jennifer Thompson     | <b>Approval Date:</b> 11/30/2016 |
| <b>Note:</b>  |  | <b>Ok to Issue:</b> <input checked="" type="checkbox"/>  |  |                                  |
| <b>Conditions:</b>  |  |  |  |                                  |
| 1) The installation of the equipment and products shall be done per the manufacturers specifications.   |  |  |  |                                  |
| 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.   |  |  |  |                                  |
| <b>Dept:</b> Fire   |  | <b>Status:</b> Approved w/Conditions   | <b>Reviewer:</b> Michael White         | <b>Approval Date:</b> 10/11/2016 |
| <b>Note:</b>  |  | <b>Ok to Issue:</b> <input checked="" type="checkbox"/>  |  |                                  |
| <b>Conditions:</b>  |  |  |  |                                  |
| 1) Fire department connection type and location shall be approved by the AHJ.   |  |  |  |                                  |
| 2) Sprinkler supervisory systems shall monitor for water flow and sprinkler supervisory signals via an approved fire alarm panel to central station. One smoke detector shall be located over the panel, a manual pull station located at the front door, and an audible water flow alarm provided. A separate Fire Alarm Permit is required from a certified fire alarm company. This review does not include approval of system design or installation. |  |  |  |                                  |
| 3) A sprinkler supervisory system shall be provided in accordance with NFPA 101, Life Safety Code, and NFPA 72, National Fire Alarm and Signaling Code.   |  |  |  |                                  |
| 4) Sprinkler system installation shall comply with NFPA 13.   |  |  |  |                                  |
| 5) All construction shall comply with 2009 NFPA 101, Chapter 9 Building Service and Fire Protection Equipment.  |  |  |  |                                  |
| 6) All construction shall comply with City Code, Chapter 10.  |  |  |  |                                  |
| 7) A Knox Box is required.  |  |  |  |                                  |