

Freedom Fire Protection, Inc.

Over 30 Years of Fire Protection Experience
77 Brown Rd. Poland, Maine 04274
Phone 207/998-9474 Fax 207/998-9473

August 13, 2018

Portland City Hall
Third Floor Room 315
Portland, Maine 04101

Attn. Mike Clinton

Ref: Rosemont Bakery
832 Stevens Avenue
Portland, Maine 04103

Subj: Sprinkler System Certification Letter

This letter is certification that sprinkler system for above referenced location was designed, calculated and installed by Freedom Fire Protection, and meets the requirements of the National Fire Protection Association 13 Standard (NFPA 13). The system was installed per the State and Local accepted drawings FP1 and FP2.

Sprinkler permit # FSP14531 was issued by the State of Maine Fire Marshal's office.

The sprinkler system was left in service by Freedom Fire Protection on September 22, 2019.

The alarm flow switch was tested and received at the fire alarm panel and monitoring company within 45 seconds.

Regards,