



**CITY OF PORTLAND**  
**STOP WORK NOTICE**

June 29, 2000

Andrzej Pospiech  
1352 Forest Ave.  
Portland, ME 04103

RE: 1352 Forest Ave.  
CBL: 294-D-003

**HAND DELIVER**

Dear Mr. Pospiech:

On June 9<sup>th</sup>, During an inspection of your property located at 1352 Forest Ave., the following violations of the National Electrical Code were found. These violations are also direct violations of Article III of the City of Portland's Building Ordinance.

This is a **STOP WORK ORDER** pursuant to Section 6-71 of the City Electrical Code. All construction activity must stop immediately.

The following issues must be corrected by a Maine licensed electrician and pass inspection within 72 hours of receipt of this letter. If work is found to be non-compliant power will be removed from the dwelling.

- NEC 230-70a: Main Distribution Panel to be located at the closest point of entry to the service conductors. A Main disconnect outside of building would also be acceptable.
- NEC 300-4: Proper installation of service entrance conductors to main breaker panel. (Box connector needed).
- ART.III, Div. I, Sec 6-34b, System must be grounded and bonded to the street side of water meter.
- Art. III, Div. I, Sec. 6-69, It is unlawful for any person to cover or conceal any wiring prior to being inspected. The walls with new wiring must be opened for inspection.
- Art. III, Div. I, Sec. 6-52, para. 3, Work done within the main electrical panel must be performed by or approved by a licensed electrician.

Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code and in Title 30-A M.R.S.A. Ss 4452. This constitutes an appealable decision pursuant to Section 121.5 of the Code. Please feel free to contact me at 874-8715, if you wish to discuss the matter or have any questions.

Sincerely,

Jeanie Bourke  
Code Enforcement Officer

Cc: Central File  
Joseph Gray



**CITY OF PORTLAND**  
**STOP WORK NOTICE**

June 20, 2000

Andrzej Pospiech  
1352 Forest Ave.  
Portland, ME 04103

RE: 1352 Forest Ave.  
CBL: 294-D-003

**HAND DELIVER**

Dear Mr. Pospiech:

During a recent inspection conducted at your property located at 1352 Forest Ave. on June 9, 2000, I found the following violations of the National Electrical Code. These conditions are direct violations of Article III, being the City of Portland's Electrical Code.

This is a **STOP WORK ORDER** pursuant to Section 6-71 of the City Electrical Code. All construction activity must Stop immediately.

The following issues must be corrected by a Maine licensed electrician and pass inspection within 24 hours. If work is found to be non-compliant power will be removed from the dwelling.

- NEC 230-70a , Main Distribution Panel to be located at the closest point of entry of the service entrance conductors. Main Disconnect outside of building would also be acceptable.
- NEC 300-4, Conductors to be properly protected and connected where they enter the Main Distribution Panel. Box connector needed.
- ART. III., DIV. I, SEC. 6-34, b. Main Panel must be grounded to the street side of the water meter.
- ART. III, DIV. I, SEC. 6-69, It is unlawful for any person to cover or conceal any wiring prior to being inspected. The basement walls with new wiring must be opened for inspection of the interconnecting conductors.
- ART.III, DIV.I, SEC. 6-52, para.3, Work done within the Main Distribution Panel must be performed by a licensed electrician, either a Licensed Master or a journeyman working for a master electrician.

## SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Alexander Rozman  
100 Bower Street  
Nashua, NH 03060  
292-D-003

2. Article Number (Copy from service label)

## COMPLETE THIS SECTION ON DELIVERY

A. Received by (Please Print Clearly) B. Date of Delivery

C. Signature

X

☐ Agent☐ Addressee

D. Is delivery address different from item 1?

☐ YesIf YES, enter delivery address below: ☐ No


3. Service Type

☒ Certified Mail☐ Express Mail☐ Registered☐ Return Receipt for Merchandise☐ Insured Mail☐ C.O.D.

4. Restricted Delivery? (Extra Fee)

☐ Yes

UNITED STATES POSTAL SERVICE



First-Class Mail  
Postage & Fees Paid  
USPS  
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •

DEPT OF PLANNING & URBAN DEVELOPMENT  
PORTLAND CITY HALL ROOM 315  
389 CONGRESS STREET  
PORTLAND, MAINE 04101

23

