

# Eastern Fire Services, Inc.



Auburn (207) 795-6324o | (207)782-0566f  
Bangor (207) 782-0566o | (207) 943-5202f  
170 Kittyhawk Ave - PO Box 1582 - Auburn, ME  
04211-1582  
www.efp-efs.com

Fire Sprinkler | Fire Alarm | Fire Suppression | Gas Detection | Burglar Alarms | CCTV | Access Control | Monitoring | Inspection, Testing, & Maintenance

## FIRE ALARM SYSTEM RECORD OF COMPLETION

### 1. PROPERTY INFORMATION

Name of property: Academy for Active Learners, LLC.

Address: 134 Warren Ave Portland, ME 04101

Description of property: Single story metal structure, not fire sprinkled.

Occupancy type: Daycare

Name of property representative: Mindy Brigham

Address: 134 Warren Ave Portland, ME 04101

Phone: (207) 854-4000 ext 6      Fax: N/A      E-mail: mindy@theacademyforactivelearners.com>

Authority having jurisdiction over this property: Portland Fire Department

Phone: 207-874-8400      Fax:      E-mail:

### 2. INSTALLATION, SERVICE, AND TESTING CONTRACTOR INFORMATION

Installation contractor for this equipment: Eastern Fire Services Inc.

Address: 170 Kitty Hawk Drive, Auburn, Maine 04210

License or certification number: N/A

Phone: 207-347-5300      Fax: 207-772-7355      E-mail: N/A

Service organization for this equipment: Eastern Fire Services Inc.

Address: 170 Kitty Hawk Drive, Auburn, Maine 04210

License or certification number: N/A

Phone: 207-347-5300      Fax: 207-772-7355      E-mail: N/A

A contract for test and inspection in accordance with NFPA standards is in effect as of: N/A

Contracted testing company: Eastern Fire Services Inc.

Address: 170 Kitty Hawk Drive, Auburn, Maine 04210

Phone: 207-347-5300      Fax: 207-772-7355      E-mail: N/A

Contract expires: N/A      Contract number: N/A      Frequency of routine inspections: N/A

### 3. DESCRIPTION OF SYSTEM OR SERVICE

Fire alarm system (nonvoice)

Fire alarm with in-building fire emergency voice alarm communication system (EVACS)

Other (specify): N/A

# Eastern Fire Services, Inc.



Auburn (207) 795-6324o | (207)782-0566f  
Bangor (207) 782-0566o | (207) 943-5202f  
170 Kittyhawk Ave - PO Box 1582 - Auburn, ME  
04211-1582  
www.efp-efs.com

Fire Sprinkler | Fire Alarm | Fire Suppression | Gas Detection | Burglar Alarms | CCTV | Access Control | Monitoring | Inspection, Testing, & Maintenance

### 3. DESCRIPTION OF SYSTEM OR SERVICE (continued)

NFPA 72 edition: 2010

Additional description of system(s): N/A

#### 3.1 Control Unit

Manufacturer: Siemens

Model number: FC 901

#### 3.2 System Documentation

An owner's manual, a copy of the manufacturer's instructions, a written sequence of operation, and a copy of the numbered record drawings are stored on site. Location: In Document Box

#### 3.3 System Software

This system does not have alterable site-specific software.

Operating system (executive) software revision level: N/A

Site-specific software revision date: N/A

Revision completed by: N/A

A copy of the site-specific software is stored on site. Location: N/A

#### 3.4 Off-Premises Signal Transmission

This system does not have off-premises transmission.

Name of organization receiving alarm signals with phone numbers:

Alarm: CentraLarm

Phone: 1-800-639-4068

Supervisory: Centralam

Phone: 1-800-639-4068

Trouble: CentraLarm

Phone: 1-800-639-4068

Entity to which alarms are retransmitted: Portland Fire Department

Phone: 207-874-8400

Method of retransmission: Pots Lines via Dispatcher (supplemental, primary communications is via City Box)

If Chapter 26, specify the means of transmission from the protected premises to the supervising station:

Private Radio Network (City Box)

### 4. CIRCUITS AND PATHWAYS

#### 4.1 Signaling Line Pathways

##### 4.1.1 Pathways Class Designations and Survivability

Pathways class: B

Survivability level: 1

Quantity: 1

(See NFPA 72, Sections 12.3 and 12.4)

##### 4.1.2 Pathways Utilizing Two or More Media

Quantity: N/A

Description: N/A

##### 4.1.3 Device Power Pathways

No separate power pathways from the signaling line pathway

Power pathways are separate but of the same pathway classification as the signaling line pathway

Power pathways are separate and different classification from the signaling line pathway

##### 4.1.4 Isolation Modules

Quantity: N/A

# Eastern Fire Services, Inc.



Auburn (207) 795-6324o | (207)782-0566f  
Bangor (207) 782-0566o | (207) 943-5202f  
170 Kittyhawk Ave - PO Box 1582 - Auburn, ME  
04211-1582  
www.efp-efs.com

Fire Sprinkler | Fire Alarm | Fire Suppression | Gas Detection | Burglar Alarms | CCTV | Access Control | Monitoring | Inspection, Testing, & Maintenance

## 4. CIRCUITS AND PATHWAYS (continued)

### 4.2 Alarm Initiating Device Pathways

#### 4.2.1 Pathways Class Designations and Survivability

Pathways class: B                      Survivability level: 1                      Quantity: 1  
(See NFPA 72, Sections 12.3 and 12.4)

#### 4.2.2 Pathways Utilizing Two or More Media

Quantity: N/A                      Description: N/A

#### 4.2.3 Device Power Pathways

- No separate power pathways from the initiating device pathway
- Power pathways are separate but of the same pathway classification as the initiating device pathway
- Power pathways are separate and different classification from the initiating device pathway

### 4.3 Non-Voice Audible System Pathways

#### 4.3.1 Pathways Class Designations and Survivability

Pathways class: B                      Survivability level: 1                      Quantity: 3  
(See NFPA 72, Sections 12.3 and 12.4)

#### 4.3.2 Pathways Utilizing Two or More Media

Quantity: N/A                      Description: N/A

#### 4.3.3 Device Power Pathways

- No separate power pathways from the notification appliance pathway
- Power pathways are separate but of the same pathway classification as the notification appliance pathway
- Power pathways are separate and different classification from the notification appliance pathway

## 5. ALARM INITIATING DEVICES

### 5.1 Manual Initiating Devices

#### 5.1.1 Manual Fire Alarm Boxes

This system does not have manual fire alarm boxes.

Type and number of devices: Addressable: 10      Conventional: N/A      Coded: N/A      Transmitter: N/A  
Other (specify): N/A

### 5.2 Automatic Initiating Devices

#### 5.2.1 Smoke Detectors

This system does not have smoke detectors.

Type and number of devices: Addressable: 16      Conventional: N/A  
Other (specify): N/A

Type of coverage:  Complete area     Partial area     Nonrequired partial area

Other (specify): N/A

Type of smoke detector sensing technology:  Ionization     Photoelectric     Multicriteria     Aspirating     Beam

Other (specify): N/A

# Eastern Fire Services, Inc.



Auburn (207) 795-6324o | (207)782-0566f  
Bangor (207) 782-0566o | (207) 943-5202f  
170 Kittyhawk Ave - PO Box 1582 - Auburn, ME  
04211-1582  
www.efp-efs.com

Fire Sprinkler | Fire Alarm | Fire Suppression | Gas Detection | Burglar Alarms | CCTV | Access Control | Monitoring | Inspection, Testing, & Maintenance

## 5. ALARM INITIATING DEVICES (continued)

### 5.2.2 Duct Smoke Detectors

This system does not have alarm-causing duct smoke detectors.

Type and number of devices: Addressable: N/A Conventional: N/A

Other (specify): N/A

Type of coverage: N/A

Type of smoke detector sensing technology:  Ionization  Photoelectric  Aspirating  Beam

### 5.2.3 Radiant Energy (Flame) Detectors

This system does not have radiant energy detectors.

Type and number of devices: Addressable: N/A Conventional: N/A

Other (specify): N/A

Type of coverage: N/A

### 5.2.4 Gas Detectors

This system does not have gas detectors.

Type of detector(s): N/A

Number of devices: Addressable: N/A Conventional: N/A

Type of coverage: N/A

### 5.2.5 Heat Detectors

This system does not have heat detectors.

Type and number of devices: Addressable: 1 Conventional: N/A

Type of coverage:  Complete area  Partial area  Nonrequired partial area  Linear  Spot

Type of heat detector sensing technology:  Fixed temperature  Rate-of-rise  Rate compensated

### 5.2.6 Addressable Monitoring Modules

This system does not have monitoring modules.

Number of devices: 1

### 5.2.7 Waterflow Alarm Devices

This system does not have waterflow alarm devices.

Type and number of devices: Addressable: N/A Conventional: N/A Coded: N/A Transmitter: N/A

### 5.2.8 Alarm Verification

This system does not incorporate alarm verification.

Number of devices subject to alarm verification: N/A Alarm verification set for: N/A seconds

### 5.2.9 Presignal

This system does not incorporate pre-signal.

Number of devices subject to presignal: N/A

Describe presignal functions: N/A

### 5.2.10 Positive Alarm Sequence (PAS)

This system does not incorporate PAS.

Describe PAS: N/A

### 5.2.11 Other Initiating Devices

This system does not have other initiating devices.

Describe: N/A

# Eastern Fire Services, Inc.



Auburn (207) 795-6324o | (207)782-0566f  
Bangor (207) 782-0566o | (207) 943-5202f  
170 Kittyhawk Ave - PO Box 1582 - Auburn, ME  
04211-1582  
www.efp-efs.com

Fire Sprinkler | Fire Alarm | Fire Suppression | Gas Detection | Burglar Alarms | CCTV | Access Control | Monitoring | Inspection, Testing, & Maintenance

## 6. SUPERVISORY SIGNAL-INITIATING DEVICES

### 6.1 Sprinkler System Supervisory Devices

This system does not have sprinkler supervisory devices.

Type and number of devices: Addressable: N/A Conventional: N/A Coded: N/A Transmitter: N/A

Other (specify): N/A

### 6.2 Fire Pump Description and Supervisory Devices

This system does not have a fire pump.

Type fire pump:  Electric pump  Engine

Type and number of devices: Addressable: N/A Conventional: N/A Coded: N/A Transmitter: N/A

Other (specify): N/A

#### 6.2.1 Fire Pump Functions Supervised

Power  Running  Phase reversal  Selector switch not in auto  Engine or control panel trouble  Low fuel

Other (specify): N/A

### 6.3 Duct Smoke Detectors (DSDs)

This system does not have DSDs causing supervisory signals.

Type and number of devices: Addressable: N/A Conventional: N/A

Other (specify): N/A

Type of coverage: N/A

Type of smoke detector sensing technology:  Ionization  Photoelectric  Aspirating  Beam

### 6.4 Other Supervisory Devices

This system does not have other supervisory devices.

Describe:

## 7. MONITORED SYSTEMS

### 7.1 Special Hazard Suppression Systems

This system does not monitor special hazard systems.

Description of special hazard system(s): Kitchen Hood Extinguishing System

### 7.2 Other Monitoring Systems

This system does not monitor other systems.

Description of special hazard system(s): N/A

## 8. ANNUNCIATORS

This system does not have annunciators.

### 8.1 Location and Description of Annunciators

Location 1: Main Entry Vestibule

Location 2: N/A

Location 3: N/A

# Eastern Fire Services, Inc.



Auburn (207) 795-6324o | (207)782-0566f  
Bangor (207) 782-0566o | (207) 943-5202f  
170 Kittyhawk Ave - PO Box 1582 - Auburn, ME  
04211-1582  
www.efp-efs.com

Fire Sprinkler | Fire Alarm | Fire Suppression | Gas Detection | Burglar Alarms | CCTV | Access Control | Monitoring | Inspection, Testing, & Maintenance

## 9. ALARM NOTIFICATION APPLIANCES

**9.1 In-Building Fire Emergency Voice Alarm Communication System**  This system does not have an EVACS.

Number of single voice alarm channels: N/A      Number of multiple voice alarm channels: N/A

Number of speakers: N/A      Number of speaker circuits: N/A

Location of amplification and sound-processing equipment: N/A

Location of paging microphone stations:

Location 1: N/A

Location 2: N/A

Location 3: N/A

**9.2 Non-voice Notification Appliances**

This system does not have nonvoice notification appliances.

Horns: N/A      With visible: 5      Bells: N/A      With visible: N/A

Chimes: N/A      With visible: N/A

Visible only: 11      Other (describe): N/A

**9.3 Notification Appliance Power Extender Panels**

This system does not have power extender panels.

Quantity: 1

Locations: Electrical Room

## 10. CONTROL FUNCTIONS

This system activates the following control functions:

Hold-open door releasing devices     Smoke management     HVAC shutdown     F/S dampers

Door unlocking     Elevator recall     Fuel source shutdown     Extinguishing agent release

Elevator shunt trip

Other (specify): N/A

**10.1 Addressable Control Modules**

This system does not have control modules.

Number of devices: N/A

Other (specify): N/A

## 11. SYSTEM POWER

**11.1 Control Unit**

**11.1.1 Primary Power**

Input voltage of control panel: 120vac      Control panel amps: 2.5

Overcurrent protection: Type: Circuit Breaker      Amps: 20

Location (of primary supply panel board): Electrical Room

Disconnecting means location: Circuit Breaker



# Eastern Fire Services, Inc.



Auburn (207) 795-6324o | (207)782-0566f  
Bangor (207) 782-0566o | (207) 943-5202f  
170 Kittyhawk Ave - PO Box 1582 - Auburn, ME  
04211-1582  
www.efp-efs.com

Fire Sprinkler | Fire Alarm | Fire Suppression | Gas Detection | Burglar Alarms | CCTV | Access Control | Monitoring | Inspection, Testing, & Maintenance

## 13. RECORD OF SYSTEM OPERATIONAL ACCEPTANCE TEST

New system

*All operational features and functions of this system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements for the following:*

Modifications to an existing system

*All newly modified operational features and functions of the system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements of the following:*

NFPA 72, Edition: 2010

NFPA 70, National Electrical Code, Article 760, Edition: 2011

Manufacturer's published instructions

Other (specify): N/A

Individual device testing documentation [Inspection and Testing Form (Figure 14.6.2.4) is attached]

Signed: *John Matthew Kempton* Printed name: John Kempton Date: 10-31-16  
Organization: EFSI, Inc. Title: Systems Technician Phone: 207-784-1507

## 14. CERTIFICATIONS AND APPROVALS

### 14.1 System Installation Contractor:

This system, as specified herein, has been installed and tested according to all NFPA standards cited herein.

Signed: *John Matthew Kempton* Printed name: John Kempton Date: 10-31-16  
Organization: EFSI, Inc. Title: Systems Technician Phone: 207-784-1507

### 14.2 System Service Contractor:

The undersigned has a service contract for this system in effect as of the date shown below.

Signed: *John Matthew Kempton* Printed name: John Kempton Date: 10-31-16  
Organization: EFSI, Inc. Title: Systems Technician Phone: 207-784-1507

### 14.3 Supervising Station:

This system, as specified herein, will be monitored according to all NFPA standards cited herein.

Signed: *John Matthew Kempton* Printed name: John Kempton Date: 10-31-16  
Organization: EFSI, Inc. Title: Systems Technician Phone: 207-784-1507





Eastern Fire Services Inc. 170 Kitty Hawk Ave, Auburn, ME 04210 207-784-1507

## FIRE ALARM SYSTEM INSPECTION AND TESTING FORM

TEST AND INSPECT JOB #	N/A	CENTRAL STATION ACCOUNT#	50602722	CITY BOX#	2179
------------------------	-----	--------------------------	----------	-----------	------

Start Date of this inspection or test: 10/11/16      Start Time of this inspection or test: 2:00PM  
End Date of this inspection or test: 10/11/16      End Time of this inspection or test: 3:30PM

### 1. PROPERTY INFORMATION

Name of property: Academy for Active Learners  
Address: 134 Warren Ave. Portland, Maine 04103  
Description of property: Single story metal structure, non-fire sprinkled  
Occupancy type: Daycare  
Name of property representative: Mindy Brigham  
Address: 134 Warren Ave. Portland, Maine 04103  
Phone: 207-874-4000      Fax: N/A      E-mail: mindy@theacademyforactivelearners.com  
Authority having jurisdiction over this property: City of Portland Fire Department  
Phone: 207-874-8576      Fax: N/A      E-mail: N/A

### 2. TESTING AND MONITORING INFORMATION

Service and/or testing organization for this equipment: Eastern Fire Services, Inc.  
Address: 170 Kitty Hawk Ave, Auburn, Maine 04210  
Phone: (207) 784-1507      Fax: (207) 782-0566      E-mail: N/A  
Service technician or tester: Joseph Correia  
Qualifications of technician or tester: Low Energy License# LM50017494  
A contract for test and inspection in accordance with NFPA standards is in effect as of:  
The contract expires: N/A      Contract number: N/A      Frequency of tests and inspections: Initial  
Monitoring organization for this equipment: CentrAlarm  
Address: 994 Candia Rd. Manchester NH 03109  
Phone: 1-800-639-2066      Fax: N/A      E-mail: N/A  
Entity to which alarms are retransmitted: City of Portland Fire Dispatch      Phone #: 207-874-8576

### 3. TYPE OF SYSTEM OR SERVICE

Fire alarm system (non-voice)

NFPA 72 edition: 2010

Additional description of system(s): Addressable Fire Alarm System w/Municipal City Box (radio)

#### 4.1 Control Unit

Manufacturer: Siemens

Model number: FC901

Location of control unit: Electrical/Mechanical Room



Eastern Fire Services Inc. 170 Kitty Hawk Ave, Auburn, ME 04210 207-784-1507

### 3. DESCRIPTION OF SYSTEM OR SERVICE (continued)

#### System Documentation

An owner's manual, a copy of the manufacturer's instructions, a written sequence of operation, and a copy of the record drawings are stored on site. Location: In document box onsite

#### 4.2 System Software / Firmware

This system does not have alterable site-specific software.

Software revision number: N/A Software last updated on: N/A

A copy of the site-specific software is stored on site. Location: EFSI, Inc. on network drive

### 4. SYSTEM POWER

#### 4.3.1 Primary Power

Input voltage of control panel: 120vac Control panel amps: 2

Location of primary power: Electrical/Mechanical Room, Panel PP1, CB #30

Over Current Protection Type: Circuit Breaker Amp Rating: 20 Disconnect Means Location: CB #30

#### 4.3.2 Secondary Power

Location: In FACP Type: SLA Nominal voltage: 12vdc Amp/hour rating: 7

Installation Date: 10/10/2016 Manufacturer: UltraTech Model #: UT-127120

Calculated capacity of batteries to drive the system:

In standby mode (hours): 24 In alarm mode (minutes): 5

Batteries are marked with date of manufacture.

#### DIGITAL ALARM COMMUNICATOR PANEL

A digital alarm communicator test results sheet is attached listing all control units tested and the results of the testing.

#### ANNUNCIATORS

This system does not have Annunciators.

#### Location and Description of Annunciators

Annunciator 1: Siemens LCD Annunciator - Main Entry/Vestibule

Annunciator 2: N/A

Annunciator 3: N/A

Annunciator 4: N/A

### 5. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring organization	Contact: CentraLarm (supplemental)	Time: N/A
Building management	Contact: Mindy Brigham	Time: N/A
Building occupants	Contact: N/A	Time: N/A
Authority having jurisdiction	Contact: City of Portland Fire Department	Time: N/A
Other, if required	Contact: N/A	Time: N/A



## 6. TESTING RESULTS

### 6.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Comments
Control unit - FACP	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Lamps/LED's / LCD's	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Fuses	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Trouble signals	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Disconnect switches/buttons	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Ground-fault monitoring	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Supervision	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Local Annunciator	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Remote Annunciators	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Power extender panels	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Pass
Isolation modules	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Other (specify): N/A	<input type="checkbox"/>	<input type="checkbox"/>	N/A

### 6.2 Secondary Power Supplies

Description	Visual Inspection	Functional Test	Comments
120-volt power	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Not measured, new installation
Generator or UPS	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Battery condition	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Not measured, new installation
Load voltage	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Not measured, new installation
Discharge test	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Not measured, new installation
Charger test	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Not measured, new installation
Other (specify): N/A	<input type="checkbox"/>	<input type="checkbox"/>	N/A

### 6.3 Combinations Systems

Description	Visual Inspection	Functional Test	Comments
Fire extinguishing monitoring devices/system	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Carbon monoxide detector/system	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Combination fire/security system	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Connected for supplemental monitoring (alarm, trouble, supervisory)
Other (specify) N/A	<input type="checkbox"/>	<input type="checkbox"/>	N/A



**6 TESTING RESULTS** *(continued)*

6.4 Special Hazard Systems

Description (specify)	Visual Inspection	Functional Test	Comments
Kitchen Hood Extinguishing System	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Electrical test @ POC
N/A	<input type="checkbox"/>	<input type="checkbox"/>	N/A
N/A	<input type="checkbox"/>	<input type="checkbox"/>	N/A

6.5 Monitored Systems

Description (specify)	Visual Inspection	Functional Test	Comments
Engine-driven generator	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Fire pump	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Special suppression systems	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Other (specify): N/A	<input type="checkbox"/>	<input type="checkbox"/>	N/A

6.6 Auxiliary Functions

Description	Visual Inspection	Functional Test	Comments
Door-releasing devices	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Fan shutdown	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Smoke management/smoke control	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Smoke damper operation	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Smoke shutter release	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Door unlocking	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Elevator recall	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Elevator shunt trip	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Other (specify): N/A	<input type="checkbox"/>	<input type="checkbox"/>	N/A

6.7 Alarm and Supervisory Alarm Initiating Device

Attach supplementary device test sheets for all initiating devices.

6.8 Notification Appliances and Power Extenders

Attach supplementary appliance test sheets for all notification appliances and power extenders.



Eastern Fire Services Inc. 170 Kitty Hawk Ave, Auburn, ME 04210 207-784-1507

**6. TESTING RESULTS (continued)**

**6.9 Supervisory Station Monitoring (Central Station)**

Description	Visual Inspection	Functional Test	Time	Comments
Alarm signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
Alarm restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
Trouble signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
Trouble restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
Supervisory signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
Supervisory restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass

**6.10 Public Emergency Alarm Reporting System (city box)**

Description	Visual Inspection	Functional Test	Time	Comments
Alarm signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
Alarm restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
City Bypass	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
City Bypass Restoral	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
City Box Tamper	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass
City Box Tamper Restoral	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	N/A	Pass

**7. NOTIFICATIONS THAT TESTING IS COMPLETE**

Monitoring organization	Contact: CentrAlarm	Time: N/A
Building management	Contact: Mindy Brigham	Time: N/A
Building occupants	Contact: N/A	Time: N/A
Authority having jurisdiction	Contact: City of Portland Fire Department	Time: N/A
Other, if required	Contact: N/A	Time: N/A

**8. SYSTEM RESTORED TO NORMAL OPERATION**

Date: 10/11/16 Time: 3:30PM

**9. CERTIFICATION**

Inspector Certification:

This system, as specified herein, has been inspected and tested according to all NFPA standards cited herein.

Signed: *Joseph Correia* Printed name: Joseph Correia Date: 10/11/16  
 Organization: Eastern Fire Services, Inc. Title: Service Technician/Tester Phone: 207-784-1507





Eastern Fire Services Inc. 170 Kitty Hawk Ave, Auburn, ME 04210 207-784-1507

## FIRE ALARM SYSTEM INITIATING DEVICE LIST

TEST AND INSPECT JOB #	N/A	CENTRAL STATION ACCOUNT#	50602722	CITY BOX#	2179
	Device Type	Address / Zone	Location/Description	Test Results Pass / Fail	
1	Smoke Detector	OH921	Mechanical Room Above FACP	Pass	
2	Monitor	FDCIO422	City Disconnect Switch	Pass	
3	Pull Station	HTRI-M/MSM-KD	Main Entry/Vestibule	Pass	
4	Smoke Detector	OH921	Main Entry/Vestibule	Pass	
5	Smoke Detector	OH921	West Corridor	Pass	
6	Heat Detector	H1921	Kitchen	Pass	
7	MO/MSM-KDNITOR	HTRI-S	Kitchen Suppression System	Pass	
8	Pull Station	HTRI-M/MSM-KD	West Exit	Pass	
9	Smoke Detector	OH921	Infant Sleeping Area	Pass	
10	Smoke Detector	OH921	Ocean Room	Pass	
11	Pull Station	HTRI-M/MSM-KD	Ocean Room Exit	Pass	
12	Smoke Detector	OH921	Farm Room	Pass	
13	Pull Station	HTRI-M/MSM-KD	Farm Room Exit	Pass	
14	Pull Station	HTRI-M/MSM-KD	South Exit	Pass	
15	Smoke Detector	OH921	South Corridor	Pass	
16	Smoke Detector	OH921	Jungle Room Front	Pass	
17	Smoke Detector	OH921	Jungle Room Back	Pass	
18	Pull Station	HTRI-M/MSM-KD	Jungle Room Exit	Pass	
19	Smoke Detector	OH921	Forest Room Back	Pass	
20	Smoke Detector	OH921	Forest Room Back	Pass	
21	Pull Station	HTRI-M/MSM-KD	Forest Room Exit	Pass	
22	Pull Station	HTRI-M/MSM-KD	Town Room Exit	Pass	
23	Smoke Detector	OH921	Town Room Back	Pass	
24	Smoke Detector	OH921	Town Room Front	Pass	
25	Smoke Detector	OH921	North Corridor by Gym	Pass	
26	Pull Station	HTRI-M/MSM-KD	Gym Front Exit	Pass	
27	Smoke Detector	OH921	Gym Right Side	Pass	
28	Smoke Detector	OH921	Gym Left Side	Pass	
29	Pull Station	HTRI-M/MSM-KD	Gym Side Exit	Pass	
30					
31					
32					
33					



Eastern Fire Services Inc. 170 Kitty Hawk Ave, Auburn, ME 04210 207-784-1507

## FIRE ALARM SYSTEM NOTIFICATION APPLIANCE/LIFE SAFETY DEVICE LIST

TEST AND INSPECT JOB #	N/A	CENTRAL STATION ACCOUNT#	50602722	CITY BOX#	2179
Device Type		Location/Description			Test Results
					Pass / Fail
1	Horn/Strobe	West Corridor by Kitchen			Pass
2	Strobe	Kitchen			Pass
3	Strobe	Ocean Room			Pass
4	Strobe	Farm Room			Pass
5	Strobe	Restroom in Farm Room			Pass
6	Horn/Strobe	South Corridor by Jungle Room			Pass
7	Strobe	South Corridor Restroom			Pass
8	Strobe	South Corridor Restroom			Pass
9	Strobe	Restroom in Jungle Room			Pass
10	Horn/Strobe	Forest Room Back			Pass
11	Strobe	Forest/Town Room Restrooms			Pass
12	Strobe	Forest/Town Room Restrooms			Pass
13	Horn/Strobe	North Corridor by Town Room			Pass
14	Strobe	Town Room			Pass
15	Horn/Strobe	Gym			Pass
16	Strobe	Gym Restroom			Pass
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					