Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/01/16

SIEMENS

D
Fire Safety & Sec

Intelligent Initiating Device

Intelligent Device Interface Module
Model HTRI-M {HTRI-MC for Canada}

ARCHITECT AND ENGINEER SPECIFICATIONS

- **Interfaces and supervises normally open (N.O.) contacts: [i.e. – fire detection] or normally closed (N.C.) contacts: [i.e. – security detection]**
- **Compact size allows mounting in single-gang box behind equipment**
- **Polarity insensitive with *SureWire*™ technology**
  - **Innovative technology supports comprehensive system and interface communication**
- **Dynamic Supervision**
- **(2) Two-wire operation**
- **Device Programmer / Test Unit programs and verifies address and test functionality**
- **UL Listed, ULC Listed; FM, CSFM and NYC Fire Department Approved**

Product Overview

The Intelligent Interface module (Model HTRI-M) is designed to provide the means of interfacing direct shorting devices to the Device Program / Test Unit (Model DPU) for various Siemens – Fire Safety fire-alarm control panels (FACPs).

Model HTRI-M provides the most advanced method of address programming and supervision – including sophisticated FACP-communication – in the fire and life safety market. Each Model HTRI-M interface module incorporates microcomputer-chip technology, and advanced bi-directional communication capabilities with the respective FACP.

Model HTRI-M is designed to monitor a N.O. or N.C. dry contact, and reports the contact status to the FACP. The microcomputer chip for Model HTRI-M has the capacity of storing – in memory – identification information, as well as integral operating-status data.

Specifications

Each Model HTRI-M interface module is programmed, via Model DPU, which is a compact, portable and menu-driven accessory that makes programming and testing a given interface more accurately and efficiently than ever before.

Model DPU eliminates the need for mechanical-addressing mechanisms — such as program jumpers, DIP switches or rotary dials — since Model DPU sets the interface address of Model HTRI-M into its microcomputer-chip, non-volatile memory electronically.

Vibration, corrosion and other conditions that deteriorate mechanical-addressing mechanisms are no longer a cause for concern. Model HTRI-M is connected to Model DPU with the programming cable provided with the tester. This programming cable (P/N 110-694927) utilizes two (2) alligator clip connectors, to attach to the HTRI-M.

SIEMENS Industry, Inc.
Building Technologies Division

Specifications — (continued)

Model HTRI-M has five (5) leads [one (1) of the five (5) leads is for grounding], which are wired to the system with user-supplied wire nuts.

Model HTRI-M is fully compatible on the same Model DLC circuit with all intelligent Siemens model 'H'-series detectors; 'HMS'-series addressable, manual stations; or any other 'H'-series addressable intelligent modules (i.e. — Model HZM or Model HCP).

Electrical Rating

Current Draw (Active or Standby):	

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/01/16

Details for Ordering

Model Number	Part Number	Description
HTRI-M	500-034000	Single-input Intelligent Interface Module
HTRI-MC	500-034000C	Single-input Intelligent Interface Module, [exclusively for Canada]

Note: Each HTRI-series model is 3.5 ounces (0.1 kilograms) for Shipping Weight.

Notice: This marketing data sheet is not intended to be used for system design or installation purposes. For the most up-to-date information, refer to each product's installation instructions.

SIEMENS Industry, Inc.
Building Technologies Division

Fire Safety
8 Fernwood Road
Florham Park, NJ 07932
Tel: (973) 593-2600
FAX: (908) 547-6877
URL: www.SBT.Siemens.com/FIS

Fire Safety
2 Kenview Boulevard
Brampton, Ontario
L6T 5E4 / Canada
Tel: (905) 799-9937
FAX: (905) 799-9858

SII-FS
Printed in U.S.A.

December 2011
Supersedes sheet dated 8/10
(Rev.2)