Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/01/16

To: Portland Fire Department

From: Eastern Fire Services

Re: Academy for Active Learners Fire Alarm Scope of Work

Date: 4/26/16

This project consists of a new single story day care being constructed at 134 Warren Ave. The building does not have an automatic fire sprinkler system but will be equipped with a fire alarm system in accordance with NFPA 101, 72 and Portland Fire Department Rules and Regulations chapter 10.

A manual fire alarm system shall be installed along with automatic detection in all common corridors, lounges, recreation areas and sleeping areas. Audio & visual notification to be installed per NFPA 72 and ADA requirements as shown on plan. Fire department notification shall be achieved through radio master box as required by city ordinance.

Please do not hesitate to contact with any questions.

Sincerely,

Colby Malcolm

malcolmcr@efp-efs.com