



Interstate
FIRE PROTECTION

P.O. Box 1005, North Conway, NH 03860 • 1-800-717-6454

P.O. Box 187, Gardiner, ME 04345 • 1-800-649-9881

E – Mail: jmooney@interstatefire.com

Fax: (603) 356-2763

November 2, 2016


City of Portland Fire Department,
389 Congress St.,
Portland, Maine, 04101
Gorham, Maine, 04038

RE: Academy of Active Learners 134 Warren Ave, Portland, Maine

To whom it may concern,

Please note that the ANSUL R-102 1.5 Gallon Kitchen Fire Suppression System installed in the 3'6" exhaust hood located in the kitchen has been installed in accordance with submitted plans to the City of Portland as well as the ANSUL R-102 Kitchen Fire Suppression Installation Manual and also complies with NFPA-17A.

Very truly yours,


John Mooney
Interstate Fire Protection