

Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 178 Warren Ave	CBL:
Exact location: (within structure) Entire Building	20 Z
Type of occupancy(s) (NFPA & ICC): NFPA 13 Ordinary hazard group 1 & 2, Light hazard	
	Allen Ave Portland.
Managing Supervisor (RMS): Ed Poulin	License No: 515
Supervisor phone: 207-998-2551	E-mail: epoulin@htfp.me
Installing contractor: High Tech Fire Protection	License No: 102
Contractor phone: 207-998-2551	E-mail: http@http.me
	vation: Addition to existing system:
This is an amendment to an existing permit: Yes: NO) Permit no:
NFPA Standard this system is designed to: 13	Edition: 2010
*Non-NFPA systems are not approved for use within the City of Portland.	COST OF WORK: \$50,000
Download a new copy of this document from	PERMIT FEE: \$520
www.portlandmaine.gov/fire for every submittal. Attach all working	(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)
documents and complete approved submittals as may be required by	State of Maine #2121085
the State Fire Marshal's Office on electronic PDF's in addition to	State of Maine #2131085 Check by mail.
full sized plans.	Check by mail.
Contractor shall verify location and type of all FDCs shall	
be approved in writing by the Fire Prevention Bureau.	
Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.	
Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with	
all fire system contractors and the Fire Department, and proper document	
All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).	
Applicant signature: Elever Ponhi Date: 5/08/2013	