

... Fire Protection by Computer Design

HTFP
84 HACKETT MILLS ROAD
POLAND 04258
207-998-2551

Job Name : Keeley Banquet Center Attic
Building : FP-01
Location : Attic space
System : #2
Contract :
Data File : DRY ATTIC.WXF

HYDRAULIC CALCULATIONS
for

Project name: Keeley Banquet Center
Location: Attic space
Drawing no: FP-01
Date: 5/8/13

Design

Remote area number: #2
Remote area location: Attic space
Occupancy classification: Light Hazard
Density: .1 - Gpm/SqFt
Area of application: 2535 - SqFt
Coverage per sprinkler: 360/ 120 - SqFt
Type of sprinklers calculated: Attic back to back + conventional uprights
No. of sprinklers calculated: 17
In-rack demand: n/a - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 517 - GPM @ 57 - Psi
Type of system: Dry system
Volume of dry or preaction system: 180 - Gal

Water supply information

Date: 5/2/2013
Location: hydrant 1516 on warren ave
Source: Portland Water District

Name of contractor: HIGH TECH FIRE PROTECTION
Address: PO BOX 156 / / MINOT, ME 04258-156
Phone number: 207-998-2551
Name of designer: Ed Poulin
Authority having jurisdiction: State of Maine/City of Portland
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

HTFP
Keeley Banquet Center Attic

Page 2
Date 3/8/13

City Water Supply:
C1 - Static Pressure : 72
C2 - Residual Pressure: 70
C2 - Residual Flow : 1255

Demand:
D1 - Elevation : 13.859
D2 - System Flow : 416.215
D2 - System Pressure : 56.601
Hose (Adj City) :
Hose (Demand) : 100
D3 - System Demand : 516.215
Safety Margin : 15.012



Fittings Used Summary

HTEP
Keeley Banquet Center Attic

Page 3
Date 3/8/13

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	
Abbrev.	Name																				
24																					
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
D	Generic Dry Pipe Valve	0	0	0	0	0	0	9.5	17	0	28	0	47	0	0	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	
61																					
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	
13																					
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	
121																					
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HTEP
Keeley Banquet Center Attic

Page 4
Date 3/8/13

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	14	21.6	na	65.07	0.2	324	21.6
DP2	-1.0	14	21.6	na	65.07	0.2	324	21.6
100	15.0	5.6	11.23	na	18.76	0.1	120	7.0
101	15.0	5.6	11.42	na	18.92	0.1	120	7.0
102	15.0	5.6	12.22	na	19.58	0.1	120	7.0
103	15.0	5.6	14.14	na	21.06	0.1	120	7.0
105	15.0	5.6	15.88	na	22.31	0.1	120	7.0
104	15.0		16.33	na				
AA	13.0		20.49	na				
110	19.0	5.6	11.47	na	18.96	0.1	120	7.0
111	19.0	5.6	11.65	na	19.12	0.1	120	7.0
112	19.0	5.6	12.49	na	19.79	0.1	120	7.0
113	19.0		13.74	na				
115	19.0	5.6	12.35	na	19.68	0.1	120	7.0
116	19.0	5.6	12.55	na	19.84	0.1	120	7.0
AB	13.0		20.81	na				
120	21.0	5.6	14.9	na	21.61	0.1	120	7.0
121	21.0	5.6	15.13	na	21.78	0.1	120	7.0
125	21.0	5.6	15.52	na	22.06	0.1	120	7.0
122	21.0		15.86	na				
AC	13.0		21.8	na				
130	23.0	8	22.6	na	38.03	0.1	360	22.6
131	23.0	8	22.64	na	38.07	0.1	360	22.6
132	23.0	8	22.79	na	38.19	0.1	360	22.6
133	23.0	8	23.1	na	38.45	0.1	360	22.6
134	23.0		25.33	na				
AD	13.0		30.38	na				
AE	13.0		30.52	na				
TOD	13.0		36.68	na				
BOD	3.0		44.4	na				
BASE	0.0		51.54	na				
HOSE	0.0		52.55	na				
H2	0.0		52.56	na				
TEST	-9.0		56.6	na	100.0			

The maximum velocity is 24.16 and it occurs in the pipe between nodes DP1 and EQ01

Final Calculations - Hazen-Williams

HTEP
Keeley Banquet Center Attic

Page 5
Date 3/8/13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
DP1 to EQ01	65.07 65.07	1.049 120.0 1.1538	1T 5.0 0.0 0.0	1.000 5.000 6.000	21.600 -0.433 6.923		K Factor = 14.00 Vel = 24.16
	0.0 65.07					28.090	K Factor = 12.28
DP2 to EQ02	65.07 65.07	1.049 120.0 1.1540	1E 2.0 0.0 0.0	0.500 2.000 2.500	21.600 -0.433 2.885		K Factor = 14.00 Vel = 24.16
	0.0 65.07					24.052	K Factor = 13.27
100 to 101	18.76 18.76	1.682 100.0 0.0162	0.0 0.0 0.0	12.000 0.0	11.226 0.0		K Factor = 5.60 Vel = 2.71
101 to 102	18.93 37.69	1.682 100.0 0.0590	1E 3.533 0.0 0.0	10.000 3.533 13.533	11.421 0.0 0.799		K Factor = 5.60 Vel = 5.44
102 to 103	19.57 57.26	1.682 100.0 0.1281	0.0 0.0 0.0	15.000 0.0 15.000	12.220 0.0 1.921		K Factor = 5.60 Vel = 8.27
103 to 104	21.06 78.32	1.682 100.0 0.2286	1T 7.065 0.0 0.0	2.500 7.066 9.566	14.141 0.0 2.187		K Factor = 5.60 Vel = 11.31
	0.0 78.32					16.328	K Factor = 19.38
105 to 104	22.31 22.31	1.682 100.0 0.0224	1T 7.065 0.0 0.0	13.000 7.066 20.066	15.878 0.0 0.450		K Factor = 5.60 Vel = 3.22
104 to AA	78.33 100.64	1.682 100.0 0.3634	1T 7.065 0.0 0.0	2.000 7.066 9.066	16.328 0.866 3.295		Vel = 14.53
AA to AB	0.0 100.64	2.635 100.0 0.0409	0.0 0.0 0.0	7.900 0.0 7.900	20.489 0.0 0.323		Vel = 5.92
	0.0 100.64					20.812	K Factor = 22.06
110 to 111	18.96 18.96	1.682 100.0 0.0166	1E 3.533 0.0 0.0	7.500 3.533 11.033	11.468 0.0 0.183		K Factor = 5.60 Vel = 2.74
111 to 112	19.12 38.08	1.682 100.0 0.0602	0.0 0.0 0.0	14.000 0.0 14.000	11.651 0.0 0.843		K Factor = 5.60 Vel = 5.50

Final Calculations - Hazen-Williams

HTEP
Keeley Banquet Center Attic

Page 6
Date 3/8/13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
112 to 113	19.79 57.87	1.682 100.0 0.1307	1T 0.0	7.065 0.0 9.566	2.500 7.066 1.250	12.494 0.0	K Factor = 5.60 Vel = 8.36
113 to AB	39.52 97.39	1.682 100.0 0.3420	1T 0.0	7.065 0.0 13.066	6.000 7.066 4.469	13.744 2.599	Vel = 14.06
	0.0 97.39					20.812	K Factor = 21.35
115 to 116	19.68 19.68	1.682 100.0 0.0177	1E 0.0	3.533 0.0 11.033	7.500 3.533 0.195	12.351 0.0	K Factor = 5.60 Vel = 2.84
116 to 113	19.84 39.52	1.682 100.0 0.0645	1T 0.0	7.065 0.0 18.566	11.500 7.066 1.198	12.546 0.0	K Factor = 5.60 Vel = 5.71
	0.0 39.52					13.744	K Factor = 10.66
AB to AC	198.03 198.03	2.635 100.0 0.1428	0.0 0.0	6.900 0.0 6.900	6.900 0.0 0.985	20.812 0.0	Vel = 11.65
	0.0 198.03					21.797	K Factor = 42.42
120 to 121	21.61 21.61	1.682 100.0 0.0211	0.0 0.0	11.000 0.0 11.000	14.896 0.0 0.232	14.896 0.0	K Factor = 5.60 Vel = 3.12
121 to 122	21.78 43.39	1.682 100.0 0.0767	1T 0.0	7.065 0.0 9.566	2.500 7.066 0.734	15.128 0.0	K Factor = 5.60 Vel = 6.27
	0.0 43.39					15.862	K Factor = 10.89
125 to 122	22.06 22.06	1.682 100.0 0.0220	1T 0.0	7.065 0.0 15.566	8.500 7.066 0.342	15.520 0.0	K Factor = 5.60 Vel = 3.19
122 to AC	43.40 65.46	1.682 100.0 0.1639	1T 0.0	7.065 0.0 15.066	8.000 7.066 2.470	15.862 3.465	Vel = 9.45
AC to AE	198.02 263.48	2.635 100.0 0.2423	0.0 0.0	36.000 0.0 36.000	36.000 0.0 8.723	21.797 0.0	Vel = 15.50
	0.0 263.48					30.520	K Factor = 47.69

Final Calculations - Hazen-Williams

HTEP
Keeley Banquet Center Attic

Page 7
Date 3/8/13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
130	38.03	2.635		6.000	22.600		K Factor = 8.00
to		100.0		0.0	0.0		
131	38.03	0.0067		6.000	0.040		Vel = 2.24
131	38.07	2.635		6.000	22.640		K Factor = 8.00
to		100.0		0.0	0.0		
132	76.1	0.0245		6.000	0.147		Vel = 4.48
132	38.18	2.635		6.000	22.787		K Factor = 8.00
to		100.0		0.0	0.0		
133	114.28	0.0517		6.000	0.310		Vel = 6.72
133	38.45	2.635	1T	11.758	13.500	23.097	K Factor = 8.00
to		100.0		0.0	11.757	0.0	
134	152.73	0.0883		0.0	25.257	2.231	Vel = 8.99
134	0.0	3.26	1X	12.469	10.500	25.328	
to		100.0		0.0	12.469	4.331	
AD	152.73	0.0313		0.0	22.969	0.720	Vel = 5.87
AD	0.0	4.26	1X	15.036	1.500	30.379	
to		100.0		0.0	15.035	0.0	
AE	152.73	0.0085		0.0	16.535	0.141	Vel = 3.44
AE	263.49	4.26	1X	15.036	79.000	30.520	
to		100.0	3V	19.171	34.205	0.0	
TOD	416.22	0.0544		0.0	113.205	6.159	Vel = 9.37
TOD	0.0	4.26	1D	26.313	6.000	36.679	
to		100.0	1B	11.277	56.384	4.331	
BOD	416.22	0.0544	1T	18.795	62.384	3.394	Vel = 9.37
BOD	0.0	4.26	1Zia	0.0	2.000	44.404	
to		120.0	3E	39.501	39.501	5.529	* Fixed loss = 4.23
BASE	416.22	0.0388		0.0	41.501	1.612	Vel = 9.37
BASE	0.0	6.16	2E	40.168	120.000	51.545	
to		140.0	1T	43.037	87.509	0.0	
HOSE	416.22	0.0048	1G	4.304	207.509	1.005	Vel = 4.48
HOSE	0.0	20.57	1T	207.444	575.000	52.550	
to		140.0		0.0	207.444	0.0	
H2	416.22	0.0		0.0	782.444	0.011	Vel = 0.40
H2	0.0	6.16	1G	4.304	5.000	52.561	
to		140.0	1E	20.084	24.388	3.898	
TEST	416.22	0.0048		0.0	29.388	0.142	Vel = 4.48
	100.00						Qa = 100.00
	516.22				56.601		K Factor = 68.62