

295-D-011

Location of Construction: Wine Manger St	Owner: Ivan Suzman	Phone: 775-6324	Permit No: 970169
Owner Address: Back Cove Estates Portland ME 04103	Lessee/Buyer's Name: IE 04103	Business Name:	<div style="border: 1px solid black; padding: 5px;"> <b>PERMIT ISSUED</b>                  MAR - 4 1997                  ZONE CODE: PORTLAND             </div>
Contractor Name: Ken Toner Inc	Address: 282 U S Rte North Freeport ME 04032	Phone: 865-9538	

Past Use: 1-fam dwlg major repairs/after fire	Proposed Use: 1-fam dwlg major repairs/after fire	COST OF WORK: \$ 100,000 FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied INSPECTION: Use Group: Type: Signature:	PERMIT FEE: \$ 520 PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: Date:
Proposed Project Description: major repairs - after fire		Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: L Chase	Date Applied For: 2/26/97	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Date: 2/26/97	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.

2. Building permits do not include plumbing, septic or electrical work.

3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

30 cy dumpster permit : \$3559 \$300

**3/8/05**

**3/8/05**

**WITH REQUIREMENTS**

**PERMIT ISSUED**

**SCANNED**

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit


Ken Toner 282 US Rt. N. Freeport 2/26/97 765-9538

Ken Toner Contractor

SIGNATURE OF APPLICANT ADDRESS: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE ADDRESS: PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector



COMMENTS

4/9/97 - Rough Plumbing / Framing ok except garage  
not moved yet  
5/29/97 - Rough framing complete incl. garage -  
ok to Close (D)

3/5/98 completed. dA

Inspection Record	
Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

# BUILDING PERMIT REPORT

DATE: 4/march/97 ADDRESS: 9 Barge ST.

REASON FOR PERMIT: Repair after fire.

BUILDING OWNER: Ivan Suzman

CONTRACTOR: Ken Toner Inc.

PERMIT APPLICANT: ↑

APPROVAL: \*1 \*3 \*6 \*8 \*10 \*11

DENIED: \*15 \*20 \*25 \*30

## CONDITION OF APPROVAL OR DENIAL

- X 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
- X 3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
- X 6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993) UL 103.
7. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
- X 8. Headroom in habitable space is a minimum of 7'6".
9. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread, 7" maximum rise.
- X 10. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
- X 11. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
12. Each apartment shall have access to two (20 separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
13. All vertical openings shall be enclosed with construction having a fire rating of at least one (1)hour, including fire doors with self closer's.
14. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
- X 15. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's building code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 13 & 19. (Smoke detectors shall be installed and maintained at the following locations):
  - In the immediate vicinity of bedrooms
  - In all bedrooms
  - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and

I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)


16. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.
17. The Fire Alarm System shall be maintained to NFPA #72 Standard.
18. The Sprinkler System shall maintained to NFPA #13 Standard.
19. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- \* 20. All construction and demolition debris must be disposed at the City's authorized reclamation site. The fee rate is attached. Proof of such disposal must be furnished to the office of Inspection Services before final Certificate of Occupancy is issued or demolition permit is granted.
21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
23. This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
24. Ventilation shall meet the requirements of Chapter 12 Sections 1210. of the City's Building Code.
- \* 25. IF any Structural member of The Framing is To be replaced  
a review From This office is required.
- \* 26. Plumbing and Electrical permit must be obtained by  
masters of their Trade.
27. \_\_\_\_\_

  
P. Samuel Hoffses, Chief of Code Enforcement

cc: Lt. McDougall, PFD  
Marge Schmuckal

I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)

16. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.
17. The Fire Alarm System shall be maintained to NFPA #72 Standard.
18. The Sprinkler System shall maintained to NFPA #13 Standard.
19. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- X 20. All construction and demolition debris must be disposed at the City's authorized reclamation site. The fee rate is attached. Proof of such disposal must be furnished to the office of Inspection Services before final Certificate of Occupancy is issued or demolition permit is granted.
21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
23. This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
24. Ventilation shall meet the requirements of Chapter 12 Sections 1210. of the City's Building Code.
- X 25. IF any structural member of the framing is to be replaced a review from this office is required.
- X 26. Plumbing and Electrical permit must be obtained by masters of their trade.
- 27.

  
\_\_\_\_\_  
P. Samuel Hoffses, Chief of Code Enforcement


cc: Lt. McDougall, PFD  
Marge Schmuckal

KEN TONER - CONTRACTOR

40' Not To Scale




20' →



← 25'

RANGE ST



Sub of 7011

Standard - 1007-100

Applicant: Ken Toner  
Address: 9 Range St

Date: 3/3/97  
C-B-L: 295-D-11:2

CHECK-LIST AGAINST ZONING ORDINANCE

Date - existing 1930

Zone Location - R-3

Interior or corner lot -

Proposed Use/Work -

Sewage Disposal -

Lot Street Frontage -

Front Yard - 25' req - 30' shown

Rear Yard - 25' req - 40' shown

Side Yard - 0' req - 16' shown

Projections -

Width of Lot -

Height - 1 story garage

Lot Area - 8,000<sup>sq</sup> per CA map

Lot Coverage/ Impervious Surface - same

Area per Family -

Off-street Parking -

Loading Bays -


Site Plan -

Shoreland Zoning/ Stream Protection -

Flood Plains -



DATE OF PLANS: FEB. 26, 1997



Upstairs layout is subject to change but will include 2 bedrooms and a full bath.

Specs.

getting interior of fire damage, smoke damage house.

Using existing door & window openings


Some changes in non-bearing interior wall

Moving 24x24 garage to new location attached to main house.

4" unforced slab with 8" reinforced perimeter & 12" rigid insulation on 3 sides

All new plumbing & electric 2004

New siding, use existing roof except some minor repairs & tie in  
stair way the same



KITCHEN AND MASTERBATH LAYOUT ARE SUBJECT TO CHANGE BUT WILL INCLUDE EVERYTHING INDICATED IN WRITTEN SPECS.

DATE OF PLANS: FEB. 26, 1997

KEN TONER  
 282 U.S. RT. 1 NORTH  
 FREEPORT, ME 04032