DEVICE WIRING DETAIL

SCALE: N.T.S.

DEVICE ELEVATION DETAIL

NOT TO SCALE

FIRE ALARM RISER DETAIL

SCALE: N.T.S.

FIRE ALARM SYSTEM LAYOUT – 1ST FLOOR

SCALE: 1/8"=1'

NOTE: FDCIO422 MODULE IS SHOWN WITHOUT COVER, REMOVE COVER TO ACCESS TERMINALS

ELECTRICAL ROOM – CITY BOX DETAIL

SCALE: NTS

NOTE: FDCIO422 MODULE IS SHOWN WITHOUT COVER, REMOVE COVER TO ACCESS TERMINALS

ELECTRICAL ROOM – SPRINKLER DETAIL

SCALE: NTS

SYMBOL LEGEND

QTY	SYMBOL	DESCRIPTION	MODEL	
1	FACP	FIRE ALARM CONTROL PANEL	FC-901	E
1	NAC	NAC POWER EXTENDER	PAD-4	ENCLOSURE
1	MST	RADIO MASTER BOX	AES	ENCLOSURE
1	P XX	SMOKE DETECTOR/BASE	OH921/ DB-11	SINGLE GANG OR OCTOGON BOX
14	F XX	MANUAL PULL STATION	MSM-KD/ HTRI-M	3.5" DEEP SINGLE GANG
12	cd	MULTI-CANDELA HORN/STROBE	ZH-MC-R	4" SQUARE
2	cd	HORN/STROBE (CEILING)	ZH-MC-CR	4" SQUARE
2	T 4	4 INPUT/OUTPUT MODULE	FDCIO422	4 11/16" SQUARE
1	cd	MULTI-CANDELA STROBE	ZR-MC-R	4" SQUARE

Reviewed for Code Compliance Fire Prevention Division Approved with Conditions

Date: 10/07/14

GENERAL NOTES	DATE	REVISIONS	REQUIRED APPROVALS	421 WARREN AVE	FIRE ALARM SYSTEM
			OWNER STATE FIRE MARSHAL LOCAL FIRE DEPARTMENT	PORTLAND, ME	PLANS & DETAILS DWG. NO. FA-1
			DRAWN BY CRM	CONTRACT WITH: ELECTRICAL SYSTEMS OF MAINE	JOB NUMBER
			CHECKED BY BWB	EASTERN FIRE SERVICES, INC. AUBURN/LEWISTON INDUSTRIAL AIRPARK, AUBURN, MAINE 04210	SCALE AS SHOWN
			CONTRACTOR LICENSE #		DATE 7/9/14