



PLAN VIEW
SCALE: $\frac{3}{32} = 1' - 0''$

NOTE:
SEE NFPA 101-2009 8.3.3 & SPEC. SHEET.
FOR SPRINKLER DETAILS APPROVED BY
STATE FIRE MARSHALS OFFICE.

- LEGEND**
- COMMON PATH POINT
 - EMERGENCY LIGHT
 - EXIT LIGHT
 - FIRE ALARM PULL BOX
-SEE FIRE/ELECTRICAL PLANS FOR STROBE LOCATIONS

Construction Type II (000)			
Multiple Occupancy: Separated			
Occupancy: Uses:	Storage and Business		
Fire Protection:	Sprinklered		
Travel Distance Limits		Storage - Low Hazard	Business
Allowed	Actual	Allowed	Actual - max
Common Path Limit	NR	N.A.	100'
Dead End Limit	NR	N.A.	50'
Travel Distance Limit	NR	85'	300'
			113'

DATE	REVISION
5/5/16	Note added
6/15/16	Noted window sprinkler code into

EST. NO.	DRAWING STATUS
16-1003	ENGINEERING DESIGNS FOR
16-1003	Safeflife Autoclave
16-1003	421 Warren Avenue
16-1003	Portland, Maine
16-1003	REVIEWED BY DS
16-1003	DATE 04/22/2016

EST. NO.	JOB NO.
16-1003	16-1003
ENGINEERING	ENGINEERING
DESIGN BUILDER	LSP

