



General location/size of 6" thick concrete pad w/# 4 rebar @ 12" e.w. for RTU-1. Coordinate size/location with mechanical contractor.

1 Floor Plan
SCALE - 3/32" = 1'-0"

Lighting Plan Key	
	2' x 4', 3-BULB FLUORESCENT LIGHT FIXTURE RECESSED INTO SUSPENDED CEILING.
	4' LONG, SURFACE-MOUNT 2-LAMP FLUORESCENT LIGHT FIXTURE WITH WRAP-AROUND LENSE
	6-LAMP, 2x4 CHAIN MOUNT, T-5 FLUORESCENT LIGHT FIXTURE.
	LED COMBO EXIT FIXTURE

KEYED NOTES - LIGHTING

- ① PROVIDE NEW HIGH OUTPUT T5, 6-BULB, 2' X 4', HIGH BAY INSTALLED WHERE INDICATED. LIGHTING SHOULD BE PLACED NEAR CENTERS OF AISLES. VERIFY EXACT FINAL LOCATION WITH SAFELITE AND CONSTRUCTION SUPERINTENDANT.
- ② NEW HIGH BAY FIXTURES SHALL BE CIRCUITED TO GENERATOR PANEL, TO PROVIDE EGRESS LIGHTING DURING POWER OUTAGE.

KEYED NOTES - ELECTRICAL

- ◇ PROVIDE QUAD RECEPTACLE AT 48" A.F.F FOR LIGHT TABLES.
- ◇ PROVIDE ELECTRICAL FOR THREE (3) FORK-LIFT BATTERY CHARGERS AT LOCATIONS SHOWN.
- ◇ PROVIDE ONE ELECTRICAL CIRCUIT IN JUNCTION BOX FOR CONNECTION TO MODULAR WILL CALL COUNTER.
- ◇ PROVIDE NEW ELECTRIC OVERHEAD DOOR OPERATORS AT LOCATIONS SHOWN.

Sheet Name		LIGHTING/POWER FULL FLOOR PLAN			
<p>BENNETT ENGINEERING MECHANICAL • ELECTRICAL (207) 865-9475</p>		<p>Safelite AutoGlass 421 Warren Avenue Portland, Maine 04103</p>			
				Issue Date: 05-04-2016	
	Revisions		Sheet No. E-1.0		
	No.	Description		Date	
	△	Egress Added		5-19-16	File
	△				Scale AS NOTED
	△				Drawn By: PMC
			Checked By: SAJ		
			Checked By: ...		