



1 Floor Plan
 SCALE - 3/32" = 1'-0"

Lighting Plan Key	
	2' x 4', 3-BULB FLUORESCENT LIGHT FIXTURE RECESSED INTO SUSPENDED CEILING.
	4' LONG, SURFACE-MOUNT 2-LAMP FLUORESCENT LIGHT FIXTURE WITH WRAP-AROUND LENSE
	6-LAMP, 2x4 CHAIN MOUNT, T-5 FLUORESCENT LIGHT FIXTURE.
	LED COMBO EXIT FIXTURE

KEYED NOTES - LIGHTING

- ① PROVIDE NEW HIGH OUTPUT T5, 6-BULB, 2' X 4', HIGH BAY INSTALLED WHERE INDICATED. LIGHTING SHOULD BE PLACED NEAR CENTERS OF AISLES. VERIFY EXACT FINAL LOCATION WITH SAFELITE AND CONSTRUCTION SUPERINTENDANT.
- ② NEW HIGH BAY FIXTURES SHALL BE CIRCUITED TO GENERATOR PANEL, TO PROVIDE EGRESS LIGHTING DURING POWER OUTAGE.

KEYED NOTES - ELECTRICAL

- ⬠ PROVIDE QUAD RECEPTACLE AT 48" A.F.F FOR LIGHT TABLES.
- ⬠ PROVIDE ELECTRICAL FOR THREE (3) FORK-LIFT BATTERY CHARGERS AT LOCATIONS SHOWN.
- ⬠ PROVIDE ONE ELECTRICAL CIRCUIT IN JUNCTION BOX FOR CONNECTION TO MODULAR WILL CALL COUNTER.
- ⬠ PROVIDE NEW ELECTRIC OVERHEAD DOOR OPERATORS AT LOCATIONS SHOWN.

Sheet Name **LIGHTING/POWER FULL FLOOR PLAN**

 BENNETT ENGINEERING MECHANICAL • ELECTRICAL (207) 865-9475	 Safelite AutoGlass 421 Warren Avenue Portland, Maine 04103

No.	Revisions		File
	Description	Date	

Drawn By: PMC	<h1>E-1.0</h1>
Checked By: SAJ	
Checked By: ...	

