

# Sequence of Operations

	84 Eastern Prom	Audio/visual activation	Activate audible/visual signal at FACP & Annunciator	Device Description at FACP & Annunciator	Shutdown of HVAC equipment	Log event in system history	Activate Elevator Fire Hat	Activate Elevator primary or secondary control	Activate Elevator shunt trip	Silence of audible devices Including FACP & annunciator	Event acknowledgement	Reset of all system functions and all visual devices	Remote transmission to Central Station A=alarm; T=trouble; S=Supervisory; L = log only	Remote indicator
Manual Pull Stations	X	X	X		X								A	
Smoke detectors common area	X	X	X		X								A	
Water Flow Monitor	X	X	X		X								A	
FACP/annunciator silence button		X	X		X				X				L	
FACP/annunciator acknowledge button		X	X		X						X			
FACP/annunciator reset button		X	X		X						X		L	
Removal of any device		X	X		X								T	
Ground fault		X	X		X								T	
System wiring "open"		X	X		X								T	
AC Power loss		X	X		X								T	
Secondary power loss		X	X		X								T	
Telephone line loss		X	X		X								T	