Maine State Security Services

A Division of L'Heureux Inc.

1308 New County RD Dayton, ME 0400
Tel: 207-247-4371
Fax: 207-929-8484
Email: info@mainestatesecurity.com

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/21/14

February 11, 2014

Portland Fire Prevention
Capt. Chris Parone
380 Congress Street
Portland, Me 04101

Re: 208 HICK STREET

Scope of work: We intend to install a Fire Alarm System for the buildings automatic extinguishing system per NFPA101 for a new Apartment buildings with 3 units and 2 stories. Per city ordinance this life safety sprinkler system needs to be supervised, we intend to monitor the electrical tamper switches and the flow switch, and install a smoke detector to cover the panel and place pull station near the sprinkler, we will also place a horn strobe in the basement of unit 1 where the riser is located. The system will be all hard wired devices all UL listed for commercial fire. Fire Alarm control panel and GSM Communicatior will be located in the basement near the riser as this building has no common space. Communication to the UL listed Central Station will be accomplished by using the Alarm net GSM Radio that is listed as a sole communication device for commercial fire.

Please feel free to give me a call after reviewing the submittals if you have any questions.

Sincerely,

Chris L'Heureux
President.