389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: Harvey Sawyer **From:** Mike Nugent

Fax: 839-5883 **Date:** December 16, 2003

Phone 839-2420 **Pages:** 1

Re: 314 Warren Ave. (296 D002)

☐ **Urgent** ☐ **For Review** ☐ **Please Comment** ☑ **Please Reply** ☐ **Please Recycle**

I have reviewed the submissions for Permit #031048 and have the following questions/comments:

1) Have these masonry walls been designed in accordance with ACI 530/ASCE 5/TMS 402.
2) Need A Statement of Special Inspections for the steel fasteners and masonry (See Section 1705.5)
3) Please complete the attached seismic profile for the project.
4) Please provide the geotechnical info that you used to base the footing design on.
5) I don't have a clear understanding of the Garage and entry door headers.