



Portland Fire Department

COUNTRY INC.
276 WARREN AVE
PORTLAND, ME 04103

RE:

256 Warren Ave Country Kitchen Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 3/27/2018 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 7/31/2018 10:00:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-Ch. 8	The fire barrier, including walls, ceilings, floors, etc. must be maintained with the minimum required fire rating.	Ceiling above the electrical room needs to be sheet rocked over.	5/28/2018
NFPA 101-9.1.2; NFPA 70	All electrical equipment must comply with the National Electric Code.	Label the electrical panels and breakers.	5/28/2018
NFPA 54	Outdoor gas lines must be protected.	Ballards are required to protect the outside propane tanks.	5/28/2018
PFD Rules, 4.2	Buildings must be clearly marked with the street address on the front of the building.		5/28/2018