

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

S & H ENTERPRISES LLC

Located at

230 WARREN AVE

PERMIT ID: 2017-00538

ISSUE DATE: 06/14/2017

CBL: 296 H001001

has permission to **Change use from autobody shop to medical marijuana cultivation facility (5,000 SF)**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Medical marijuana cultivation facility

Building Inspections

Use Group: S-1 **Type:** 5B
Storage Moderate Hazard - medical marijuana grower
Occupant Load = 10
Nonsprinkled
Entire
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Electrical Close-in

Certificate of Occupancy/Final Inspection

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00538	Date Applied For: 04/19/2017	CBL: 296 H001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Medical marijuana cultivation facility	Proposed Project Description: Change use from autobody shop to medical marijuana cultivation facility (5,000 SF)			
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 05/03/2017 Note: B-4 zone Ok to Issue: <input checked="" type="checkbox"/> Use allowed per §14-229.11(a)(23) Off-street parking: floor area 5,000 sf = 2 parking spaces required. Lot has 12+ spaces - OK Conditions: 1) This property shall remain a medical marijuana cultivation facility. Any change of use shall require a separate permit application for review and approval. 2) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only. 3) Separate permits shall be required for any new signage. 4) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Jeanie Bourke Approval Date: 06/13/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) Wiring installations for this project or occupancy shall comply with the 2014 National Electric Code. Existing conditions for new occupancies will be required to be upgraded to prescribed standards. Loading calculations may need to be provided prior to any electrical installations. Please contact the City electrical inspectors with any questions. 3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS Status: Not Applicable Reviewer: Rachel Smith Approval Date: 04/21/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 207-874-8801.				
Dept: Fire Status: Approved w/Conditions Reviewer: Jason Grant Approval Date: 06/13/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Any grow rooms that have an artificially created atmosphere to enhance the growing process that are hazardous or potentially hazardous to people shall have a NFPA 704 placard describing the hazard and it hazard level posted at the entrance to the room. 2) The means of egress shall be illuminated and marked in accordance with 2009 NPFA 101, sections 7.8 and 7.10. 7.8.1.3 The minimum illumination of the egress path for stairs shall be at least 10 ft-candle and the minimum illumination of the egress path of floors and other walking surfaces other than stairs shall be at least 1 ft-candle. 3) Fire extinguishers are required per NFPA 1 (2009 Edition) Table 13.6.2. The quantity, size, type and location shall be in accordance with NFPA 1, 13.6.8. For light or ordinary hazard buildings a 2-A rated extinguisher (5lb. Dry Chemical Ext.) is required no more than 75 feet of travel distance from anywhere in the building and at least 1 extinguisher per story.				

PERMIT ID: 2017-00538

Located at: 230 WARREN AVE

CBL: 296 H001001

- 4) All construction shall comply with City Code, Chapter 10.
All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 40 and other applicable chapters
All construction shall comply with 2009 NFPA 1, Fire Code.
This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).
All means of egress to remain accessible at all times.
If applicable, all outstanding code violations shall be corrected prior to final inspection.
- 5) This building permit does not approve any THC extraction processes in the building. Additional permitting would be required for any THC extraction this process.