

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

BERENSON TERI E

**Located at**

202 WARREN AVE (suite 100)

**PERMIT ID:** 2013-01579

**ISSUE DATE:** 02/16/2017

**CBL:** 296 H012001

has permission to **Suite 100, Change of Use from offices to Hair Salon**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Chris Pirone*

**Fire Official**

*/s/ Jeanie Bourke*

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Suite 100 - hair salon

***Building Inspections***

**Use Group:** B

**Type:** 3B

Business - salon

Occupant Load = 7

NFPA 13 sprinkler system

First Floor - right end

MUBEC/IBC 2009

***Fire Department***

**Classification:**

Class C Mercantile

ENTIRE

2009 NFPA

**PERMIT ID:** 2013-01579

**Located at:** 202 WARREN AVE (suite 100)

**CBL:** 296 H012001

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status of Permit or Schedule an Inspection at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

### **REQUIRED INSPECTIONS:**

Certificate of Occupancy/Final Inspection

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

|  |                                      |   |  |   |
|--|--------------------------------------|---|--|---|
| <b>City of Portland, Maine - Building or Use Permit</b>  |                                      | <b>Permit No:</b><br>2013-01579   | <b>Date Applied For:</b><br>07/23/2013 | <b>CBL:</b><br>296 H012001                              |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716  |                                      |   |  |   |
| <b>Proposed Use:</b><br>To add personal service of a hair salon and Spa to unoccupied space  |                                      | <b>Proposed Project Description:</b><br>Suite 100, Change of Use from offices to Hair Salon |  |   |
| <hr/>  |                                      |   |  |   |
| <b>Dept:</b> Zoning  | <b>Status:</b> Approved w/Conditions | <b>Reviewer:</b> Marge Schmuckal  | <b>Approval Date:</b> 07/26/2013       | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |
| <b>Note:</b>   |                                      |   |  |   |
| <b>Conditions:</b>   |                                      |   |  |   |
| 1) Separate permits shall be required for any new signage.   |                                      |   |  |   |
| <hr/>  |                                      |   |  |   |
| <b>Dept:</b> Building Inspecti   | <b>Status:</b> Approved w/Conditions | <b>Reviewer:</b> Jeanie Bourke  | <b>Approval Date:</b> 02/16/2017       | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |
| <b>Note:</b>   |                                      |   |  |   |
| <b>Conditions:</b>   |                                      |   |  |   |
| 1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.   |                                      |   |  |   |
| <hr/>  |                                      |   |  |   |
| <b>Dept:</b> Fire  | <b>Status:</b> Approved w/Conditions | <b>Reviewer:</b> Chris Pirone   | <b>Approval Date:</b> 07/30/2013       | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |
| <b>Note:</b>   |                                      |   |  |   |
| <b>Conditions:</b>   |                                      |   |  |   |
| 1) Fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions or any other wall required to have protected openings or penetrations shall be effectively and permanently identified with signs or stenciling in accessible concealed floor, floor-ceiling or attic spaces at intervals not exceeding 30 feet with lettering not less than 0.5 inches in height.   |                                      |   |  |   |
| 2) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer. Contact Michelle Sweeney at 874-8682 for further information.  |                                      |   |  |   |
| 3) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.   |                                      |   |  |   |
| 4) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.   |                                      |   |  |   |
| 5) Fire department connection type and location shall be approved in writing by Fire Prevention Bureau.  |                                      |   |  |   |
| 6) Fire extinguishers are required per NFPA 1.   |                                      |   |  |   |
| 7) All means of egress to remain accessible at all times.  |                                      |   |  |   |
| 8) Construction or installation shall comply with City Code Chapter 10.  |                                      |   |  |   |
| 9) Any cutting and welding done will require a Hot Work Permit from Fire Department.   |                                      |   |  |   |
| 10 Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.  |                                      |   |  |   |
| 11 Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals. |                                      |   |  |   |
| 12 **The fire alarm system design shall be evaluated for the renovated areas by an NICET IV certified interior fire alarm designer or a licensed engineer for compliance with the code. A compliance letter is required prior to the final inspection.**<br>**A current inspection sticker from an approved fire alarm inspection company is required prior to the final inspection.**   |                                      |   |  |   |
| 13 The approved plans with the Building Department Approved stamp shall be maintained on site for inspection.  |                                      |   |  |   |
| 14 Shall comply with 2009 NFPA 101 Chapter 37 Existing Mercantile Occupancy  |                                      |   |  |   |
| 15 Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.  |                                      |   |  |   |

**PERMIT ID:** 2013-01579

**Located at:** 202 WARREN AVE (suite 100)

**CBL:** 296 H012001

