


Overall Length: 28 0 0



All locations are measured from the outside face of left support (or left cantilever end). All dimensions are horizontal.

Design Results	Actual @ Location	Allowed	Result	LDF	Load: Combination (Pattern)
Member Reaction (lbs)	778 @ 0 4 8	1725 (3.50")	Passed (45%)	1.00	1.0 D + 1.0 L (All Spans)
Shear (lbs)	758 @ 0 5 8	2710	Passed (28%)	1.00	1.0 D + 1.0 L (All Spans)
Moment (Ft-lbs)	5198 @ 14 0 0	12925	Passed (40%)	1.00	1.0 D + 1.0 L (All Spans)
Live Load Defl. (in)	0.396 @ 14 0 0	0.681	Passed (L/826)	--	1.0 D + 1.0 L (All Spans)
Total Load Defl. (in)	0.554 @ 14 0 0	1.362	Passed (L/590)	--	1.0 D + 1.0 L (All Spans)
TJ-Pro™ Rating	37	35	Passed	--	--

System : Floor  
 Member Type : Joist  
 Building Use : Residential  
 Building Code : IBC 2009  
 Design Methodology : ASD

- Deflection criteria: LL (L/480) and TL (L/240).
- Bracing (Lu): All compression edges (top and bottom) must be braced at 7 11 9 o/c unless detailed otherwise. Proper attachment and positioning of lateral bracing is required to achieve member stability.
- A structural analysis of the deck has not been performed.
- Deflection analysis is based on composite action with a single layer of 23/32" Weyerhaeuser Edge™ Panel (24" Span Rating) that is glued and nailed down.
- Additional considerations for the TJ-Pro™ Rating include: 5/8" Gypsum ceiling, 1x4 Flat strapping.

Supports	Bearing Length			Loads to Supports (lbs)			Accessories
	Total	Available	Required	Dead	Floor Live	Total	
1 - Stud wall - SPF	5.50"	4.25"	1.75"	224	560	784	1 1/4" Rim Board
2 - Stud wall - SPF	5.50"	4.25"	1.75"	224	560	784	1 1/4" Rim Board

- Rim Board is assumed to carry all loads applied directly above it, bypassing the member being designed.

Loads	Location (Side)	Spacing	Dead (0.90)	Floor Live (1.00)	Comments
1 - Uniform (PSF)	0 0 0 to 28 0 0	16"	12.0	30.0	Residential - Sleeping Areas

Member Notes
Envy Construction Cunningham Job Portland, Me

Weyerhaeuser Notes
Weyerhaeuser warrants that the sizing of its products will be in accordance with Weyerhaeuser product design criteria and published design values. Weyerhaeuser expressly disclaims any other warranties related to the software. Refer to current Weyerhaeuser literature for installation details. (www.woodbywy.com) Accessories (Rim Board, Blocking Panels and Squash Blocks) are not designed by this software. Use of this software is not intended to circumvent the need for a design professional as determined by the authority having jurisdiction. The designer of record, builder or framer is responsible to assure that this calculation is compatible with the overall project. Products manufactured at Weyerhaeuser facilities are third-party certified to sustainable forestry standards. Weyerhaeuser Engineered Lumber Products have been evaluated by ICC ES under technical reports ESR-1153 and ESR-1387 and/or tested in accordance with applicable ASTM standards. For current code evaluation reports refer to <a href="http://www.woodbywy.com/services/s_CodeReports.aspx">http://www.woodbywy.com/services/s_CodeReports.aspx</a> . The product application, input design loads, dimensions and support information have been provided by Forte Software Operator



Forte Software Operator	Job Notes
Chris Burnett Hammond Lumber Company (207) 495-3303 cburnett@hammondlumber.com	