

---

## Fwd: Licensed capacity

---

Jennifer Doane <jdoaneluna@gmail.com>  
To: "bstephens@portlandmaine.gov" <bstephens@portlandmaine.gov>

Fri, Jan 26, 2018 at 2:09 PM

----- Forwarded message -----

From: Danaher, Katie <Katie.Danaher@maine.gov>  
Date: Fri, Jan 26, 2018 at 2:01 PM  
Subject: RE: Licensed capacity  
To: Jennifer Doane <jdoaneluna@gmail.com>

Hi Jennifer,

This email serves as verification that you passed a fire inspection in 2015 with the license application indicating a goal of 6 child capacity. The 2015 inspection was completed by Mike Minkowski, who is no longer employed at the SOM. Following that inspection your licensed capacity was set at 5 children because of the City of Portland's Occupancy permit allowed 4 non-related children and the 5<sup>th</sup> child considered for the license was your birth child.

On January 23, 2018 I went to the child care to verify the maximum capacity of children your home could accommodate based on 35 sq ft/child. In measuring 3 rooms primarily used for child care you have space for 11 children, excluding the children's kitchen dining area.

Please feel free to forward this information to the code office for their verification process.

Be well,

Katie

**Katie Danaher, LSW**

Child Care Licensing Specialist

Department of Health and Human Services

***Maine Center for Disease Control and Prevention - Preserve ~ Promote ~ Protect***

Division of Environmental and Community Health

Children's Licensing and Investigation Services