

**. . . Fire Protection by Computer Design**

Dean & Allyn, Inc.  
116 Lewiston Road  
Gray, ME 04039  
(207) 657-5646

Job Name : C171418 1576 Forest Ave  
Drawing : 1 of 2  
Location : 1576 Forest Avenue  
Remote Area : Area 3  
Contract : C171418  
Data File : Wet System - Area 3.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** Moran's Market Renovations  
**Location:** 1576 Forest Avenue  
**Drawing no:** 1 of 2  
**Date:** 11/14/2017

**Design**

**Remote area number:** Area 3  
**Remote area location:** First Floor Kitchen  
**Occupancy classification:** Ordinary Hazard Group II  
**Density:** 0.20 - Gpm/SqFt  
**Area of application:** 960 - SqFt  
**Coverage per sprinkler:** 130 - SqFt  
**Type of sprinklers calculated:** Reliable F1FR56 Pendent  
**No. of sprinklers calculated:** 15  
**In-rack demand:** - GPM  
**Hose streams:** 250 - GPM  
**Total water required (including hose streams):** 688.575 - GPM @ 60.045 - Psi  
**Type of system:** Wet  
**Volume of dry or preaction system:** N/A - Gal

**Water supply information**

**Date:** 10/14/2016  
**Location:** Forest Avenue - Hydrant #01652  
**Source:** Portland Water District

**Name of contractor:** Dean & Allyn, Inc.  
**Address:** 116 Lewiston Road / / Gray, ME 04039  
**Phone number:** (207) 657-5646  
**Name of designer:** Chris Stewart  
**Authority having jurisdiction:**  
**Notes: (Include peaking information or gridded systems here.)**

# Water Supply Curve C

Dean & Allyn, Inc.  
C171418 1576 Forest Ave


Page 2  
Date 11/14/17

## City Water Supply:

C1 - Static Pressure : 75  
C2 - Residual Pressure: 74  
C2 - Residual Flow : 1244

## Demand:

D1 - Elevation : 3.716  
D2 - System Flow : 438.575  
D2 - System Pressure : 60.045  
Hose ( Demand ) : 250  
D3 - System Demand : 688.575  
Safety Margin : 14.620



# Fittings Used Summary

Dean & Allyn, Inc.  
C171418 1576 Forest Ave

Page 3  
Date 11/14/17

## Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

## Unit Summary

Diameter Units           Inches  
Length Units             Feet  
Flow Units               US Gallons per Minute  
Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Dean & Allyn, Inc.  
C171418 1576 Forest Ave

Page 4  
Date 11/14/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP03	15.37	5.6	16.58	na	22.8	0.2	114	7.0
EQ03	16.08		16.71	na				
DP02	15.37	5.6	7.0	na	14.82	0.2	57	7.0
EQ02	16.08		7.12	na				
DP01	15.37	5.6	11.03	na	18.6	0.2	93	7.0
EQ01	16.08		11.37	na				
123	13.08	5.6	14.99	na	21.68	0.2	71	7.0
124	13.08		15.87	na				
125	16.08		22.27	na				
126	16.08		22.49	na				
127	16.08		37.3	na				
128	16.08		41.72	na				
129	6.25		47.85	na				
130	6.25		49.31	na				
TR2	4.0		51.86	na				
BR2	1.5		59.2	na				
FF	1.5		62.07	na				
UG1	1.5		62.62	na				
TEST	7.5		60.05	na	250.0			
131	13.08	5.6	15.72	na	22.2	0.2	71	7.0
132	16.08	5.6	18.37	na	24.0	0.2	120	7.0
133	16.08		19.94	na				
134	16.08	5.6	18.76	na	24.25	0.2	59	7.0
135	16.08	5.6	21.4	na	25.9	0.2	120	7.0
136	16.08	5.6	29.96	na	30.65	0.2	100	7.0
137	16.08	5.6	32.83	na	32.09	0.2	100	7.0
138	16.08	5.6	34.7	na	32.99	0.2	119	7.0
139	16.08	5.6	34.07	na	32.69	0.2	60	7.0
140	16.08	5.6	36.65	na	33.9	0.2	77	7.0
141	16.08	K = K @ EQ02	29.53	na	30.18			
142	16.08		32.58	na				
143	16.08	K = K @ EQ01	33.82	na	32.08			
144	16.08		38.62	na				
145	16.08		44.2	na				
146	16.08		44.48	na				
147	16.08	5.6	32.3	na	31.83	0.2	57	7.0
148	16.08		44.18	na				
149	15.33	5.6	30.64	na	31.0	0.2	42	7.0
150	16.08	K = K @ EQ03	35.3	na	33.14			
151	16.08		41.21	na				
152	16.08		42.8	na				

The maximum velocity is 24.72 and it occurs in the pipe between nodes 140 and 127

EOD

Dean & Allyn, Inc.  
C171418 1576 Forest Ave

Page 5  
Date 11/14/17

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP03 to EQ03	15.370 16.080	5.60	22.80 22.8	1 1.049	E	2.0 0.0 0.0	0.670 2.000 2.670	120	16.576 -0.308 0.444		Vel = 8.46	
EQ03			0.0 22.80						16.712		K Factor = 5.58	
DP02 to EQ02	15.370 16.080	5.60	14.82 14.82	1 1.049	T	5.0 0.0 0.0	0.670 5.000 5.670	120	7.000 -0.308 0.424		Vel = 5.50	
EQ02			0.0 14.82						7.116		K Factor = 5.56	
DP01 to EQ01	15.370 16.080	5.60	18.60 18.6	1 1.049	T	5.0 0.0 0.0	0.670 5.000 5.670	120	11.032 -0.308 0.646		Vel = 6.90	
EQ01			0.0 18.60						11.370		K Factor = 5.52	
123 to 124	13.080 13.080	5.60	21.68 21.68	1 1.049		0.0 0.0 0.0	5.850 0.0 5.850	120	14.988 0.0 0.884		Vel = 8.05	
124 to 125	13.080 16.080		22.21 43.89	1 1.049	T 2E	5.0 4.0 0.0	4.830 9.000 13.830	120	15.872 -1.299 7.702		Vel = 16.29	
125 to 126	16.080 16.080		48.25 92.14	1.5 1.61		0.0 0.0 0.0	0.790 0.0 0.790	120	22.275 0.0 0.215		Vel = 14.52	
126 to 127	16.080 16.080		25.90 118.04	1.5 1.61	2T 3E	16.0 12.0 0.0	6.350 28.000 34.350	120	22.490 0.0 14.812		Vel = 18.60	
127 to 128	16.080 16.080		66.59 184.63	2 2.067	T	10.0 0.0 0.0	5.120 10.000 15.120	120	37.302 0.0 4.417		Vel = 17.65	
128 to 129	16.080 6.250		95.73 280.36	3 3.26	J	17.471 0.0 0.0	9.830 17.471 27.301	120	41.719 4.257 1.879		Vel = 10.78	
129 to 130	6.250 6.250		0.0 280.36	4 4.26	4I	36.868 0.0 0.0	40.790 36.868 77.658	120	47.855 0.0 1.452		Vel = 6.31	
130 to TR2	6.250 4		158.22 438.58	4 4.26	2I	18.434 0.0 0.0	18.500 18.434 36.934	120	49.307 0.974 1.580		Vel = 9.87	
TR2 to BR2	4 1.500		0.0 438.58	4 4.26	B S Fsp T	15.8 28.968 0.0 26.334	5.000 71.102 76.102	120	51.861 4.083 3.255		* Fixed Loss = 3 Vel = 9.87	
BR2 to FF	1.500 1.500		0.0 438.58	6 6.357	2E Zca	35.205 0.0 0.0	8.000 35.205 43.205	120	59.199 2.611 0.264		* Fixed Loss = 2.611 Vel = 4.43	
FF to UG1	1.500 1.500		0.0 438.58	6 6.16	E T	20.084 43.037 0.0	40.000 63.121 103.121	140	62.074 0.0 0.550		Vel = 4.72	

# Final Calculations - Hazen-Williams

Dean & Allyn, Inc.  
C171418 1576 Forest Ave

Page 6  
Date 11/14/17

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG1 to TEST	1.500 7.500		0.0 438.58	16 16.41	E T G	82.4 166.859 16.48	175.000 265.740 440.740	140 0	62.624 -2.599 0.020		Vel = 0.67	
TEST			250.00 688.58						60.045		Qa = 250.00 K Factor = 88.86	
131 to 124	13.080 13.080	5.60	22.20 22.2	1 1.049		0.0 0.0 0.0	0.950 0.0 0.950	120 0.1579	15.722 0.0 0.150		Vel = 8.24	
124			0.0 22.20						15.872		K Factor = 5.57	
132 to 133	16.080 16.080	5.60	24.00 24.0	1 1.049	E	2.0 0.0 0.0	6.600 2.000 8.600	120 0.1823	18.367 0.0 1.568		Vel = 8.91	
133 to 125	16.080 16.080		24.25 48.25	1.25 1.38	T	6.0 0.0 0.0	7.400 6.000 13.400	120 0.1746	19.935 0.0 2.340		Vel = 10.35	
125			0.0 48.25						22.275		K Factor = 10.22	
134 to 133	16.080 16.080	5.60	24.25 24.25	1 1.049	T	5.0 0.0 0.0	1.330 5.000 6.330	120 0.1859	18.758 0.0 1.177		Vel = 9.00	
133			0.0 24.25						19.935		K Factor = 5.43	
135 to 126	16.080 16.080	5.60	25.90 25.9	1 1.049		0.0 0.0 0.0	5.210 0.0 5.210	120 0.2100	21.396 0.0 1.094		Vel = 9.61	
126			0.0 25.90						22.490		K Factor = 5.46	
136 to 137	16.080 16.080	5.60	30.65 30.65	1 1.049		0.0 0.0 0.0	10.000 0.0 10.000	120 0.2867	29.962 0.0 2.867		Vel = 11.38	
137 to 138	16.080 16.080	5.60	32.09 62.74	1.25 1.38	E	3.0 0.0 0.0	3.580 3.000 6.580	120 0.2837	32.829 0.0 1.867		Vel = 13.46	
138 to 128	16.080 16.080	5.60	32.98 95.72	1.25 1.38	T	6.0 0.0 0.0	5.330 6.000 11.330	120 0.6199	34.696 0.0 7.023		Vel = 20.53	
128			0.0 95.72						41.719		K Factor = 14.82	
139 to 140	16.080 16.080	5.60	32.69 32.69	1 1.049		0.0 0.0 0.0	8.000 0.0 8.000	120 0.3230	34.068 0.0 2.584		Vel = 12.14	
140 to 127	16.080 16.080	5.60	33.90 66.59	1 1.049		0.0 0.0 0.0	0.540 0.0 0.540	120 1.2037	36.652 0.0 0.650		Vel = 24.72	
127			0.0 66.59						37.302		K Factor = 10.90	

# Final Calculations - Hazen-Williams

Dean & Allyn, Inc.  
C171418 1576 Forest Ave

Page 7  
Date 11/14/17

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
141 to 142	16.080 16.080	5.55	30.18	1	E T	2.0 5.0	3.950 7.000	120	29.526 0.0		K = K @ EQ02	
			30.18	1.049		0.0	10.950	0.2785	3.050		Vel = 11.20	
142 to 143	16.080 16.080		31.83	1.25		0.0 0.0	4.470 0.0	120	32.576 0.0			
			62.01	1.38		0.0	4.470	0.2776	1.241		Vel = 13.30	
143 to 144	16.080 16.080	5.52	32.07	1.25		0.0 0.0	8.000 0.0	120	33.817 0.0		K = K @ EQ01	
			94.08	1.38		0.0	8.000	0.6004	4.803		Vel = 20.18	
144 to 145	16.080 16.080		0.0	1.5	T	8.0 0.0	11.670 8.000	120	38.620 0.0			
			94.08	1.61		0.0	19.670	0.2834	5.575		Vel = 14.83	
145 to 146	16.080 16.080		64.14	2.5		0.0 0.0	4.290 0.0	120	44.195 0.0			
			158.22	2.635		0.0	4.290	0.0674	0.289		Vel = 9.31	
146 to 130	16.080 6.250		0.0	4	5I J	46.085 21.067	20.000 67.152	120	44.484 4.257			
			158.22	4.26		0.0	87.152	0.0065	0.566		Vel = 3.56	
130			0.0 158.22						49.307		K Factor = 22.53	
147 to 142	16.080 16.080	5.60	31.83	1		0.0 0.0	0.900 0.0	120	32.300 0.0			
			31.83	1.049		0.0	0.900	0.3067	0.276		Vel = 11.82	
142			0.0 31.83						32.576		K Factor = 5.58	
145 to 148	16.080 16.080		-64.13	2.5		0.0 0.0	1.000 0.0	120	44.195 0.0			
			-64.13	2.635		0.0	1.000	-0.0130	-0.013		Vel = 3.77	
148			0.0 -64.13						44.182		K Factor = -9.65	
149 to 150	15.330 16.080	5.60	31.00	1	3E	6.0 0.0	11.040 6.000	120	30.638 -0.325			
			31.0	1.049		0.0	17.040	0.2927	4.988		Vel = 11.51	
150 to 151	16.080 16.080	5.58	33.13	1.25		0.0 0.0	20.000 0.0	120	35.301 0.0		K = K @ EQ03	
			64.13	1.38		0.0	20.000	0.2955	5.910		Vel = 13.76	
151 to 152	16.080 16.080		0.0	1.5	T	8.0 0.0	3.420 8.000	120	41.211 0.0			
			64.13	1.61		0.0	11.420	0.1395	1.593		Vel = 10.11	
152 to 148	16.080 16.080		0.0	2	4E	20.0 0.0	13.370 20.000	120	42.804 0.0			
			64.13	2.067		0.0	33.370	0.0413	1.378		Vel = 6.13	
148			0.0 64.13						44.182		K Factor = 9.65	