

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 15 Wirt St Verrill St/Wirt St		Owner: David Chase	Phone: 797-9093	Permit No: 990288
Owner Address: 50 Gray St Falmouth ME 04105	Lessee/Buyer's Name:	Phone:	BusinessName:	
Contractor Name: SAA	Address:	Phone:	Permit Issued:	
Past Use: Vacant	Proposed Use: 1-Family	COST OF WORK: \$ 55,000	PERMIT FEE: \$ 295.00	
		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: 43 Type 5B BOCA 96	Zone: CBL: 299-0023
Proposed Project Description: Construct single family dwelling		Signature:	Signature: [Signature]	Zoning Approval: [Signature]
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>
Permit Taken By: SP	Date Applied For: March 15, 1999	Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>	Signature: Date:	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

March 15, 1999

SIGNATURE OF APPLICANT	ADDRESS:	DATE:	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

Zoning Appeal

Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation

Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:

Approved
 Approved with Conditions
 Denied

Date: [Signature]

CEO DISTRICT

COMMENTS

4/26/99 Foundation Inspection Setbacks OK drainage & dampproof to be installed 4/27/99 (K)

5/14/99 Elect. problem w/ several boxes. Pl. problem w/ protection from sheet rocks. Framing needs more layers. Question on egress windows. aca / M.J.N.

7/28/99 Final require attic scuttle, as built plans include deck, firestop chimney in basement, adjust side stairs, egress windows OK (D) David Chase notified via VocoMail 7/29

to 9/23/99 OK for COPO (K)

1/20/00 David Chase dropped off as built plans (JB)

Inspection Record		Date
Type		
Foundation:	_____	_____
Framing:	_____	_____
Plumbing:	_____	_____
Final:	_____	_____
Other:	_____	_____



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 15 Wirt Street CBL#299-D-023

Issued to David Chase

Date of Issue 9-24-99

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 990288, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

APPROVED OCCUPANCY

Single Family Dwelling
Use Group R-3
Type 5B
Boca 96

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

9/24/99

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

6/9/00

6/9/00

BUILDING PERMIT REPORT

DATE: 17 Mar 99 ADDRESS: Verrill St / Wirt St. CBL: 299-D-023
 REASON FOR PERMIT: Single Family dwelling
 BUILDING OWNER: David Chase
 PERMIT APPLICANT: ↑
 USE GROUP R-3 BOCA 1996 CONSTRUCTION TYPE 5B

CONDITION(S) OF APPROVAL

This permit is being issued with the understanding that the following conditions are met:

Approved with the following conditions: *1, 2, 3, 4, 5, 6, 9, 11, 13, 14, 15, 19, 27, 28, 29, 30, 31, 32, 33*

- X 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- X 2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
- X 3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
- X 4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' o.c. between bolts. (Section 2305.17)
- X 5. Waterproofing and damp proofing shall be done in accordance with Section 1813.0 of the building code.
- X 6. Precaution must be taken to protect concrete from freezing. Section 1908.0
7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1996)
- X 9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
- X 11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2, M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 3e4" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)
12. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
- X 13. Stair construction in **Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise.** All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)
- X 14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4
- X 15. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)
16. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
17. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) (Section 710.0)

18. The boiler shall be protected by enclosing with (1)hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1)

X 19. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):

- In the immediate vicinity of bedrooms
- In all bedrooms
- In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2.

20. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)

21. The Fire Alarm System shall maintained to NFPA #72 Standard.

22. The Sprinkler System shall maintained to NFPA #13 Standard.

23. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1996)

24. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".

25. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.

26. Ventilation shall meet the requirements of Chapter 12 Sections 1210.0 of the City's Building Code. (Crawl spaces & attics).

X 27. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. **No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.**

X 28. All requirements must be met before a final Certificate of Occupancy is issued.

X 29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (the BOCA National Building Code/1996).

30. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)

X 31. Please read and implement the attached Land Use Zoning report requirements. → See Attached

X 32. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.5.3 of the City's Building Code.

X 33. Glass and glazing shall meet the requirements of Chapter 24 of the building code.

34. _____


35. _____

36. _____

P. Samuel Hoffses, Building Inspector
 cc: Lt. McDougall, PFD
 Marge Schmuckal, Zoning Administrator

* **On the basis of plans submitted and conditions placed on these plans any deviations shall require a separate approval.

1



DeLUCA-HOFFMAN ASSOCIATES, INC.
CONSULTING ENGINEERS

772 MAIN STREET
SUITE 4
SOUTH PORTLAND, MAINE 04106
TEL. 207 773 1112
FAX 207 879 0895

- ROADWAY DESIGN
- ENVIRONMENTAL ENGINEERING
- TRAFFIC STUDIES AND MANAGEMENT
- PERMITTING
- AIRPORT ENGINEERING
- SITE PLANNING
- CONSTRUCTION ADMINISTRATION

MEMORANDUM

299-D-023

TO: Code Enforcement
Kandi Talbot, Planner

FROM: Jim Wendel, P.E. Development Review Coordinator

DATE: September 22, 1999

RE: Certificate of Occupancy
15 Wirt Street (lot 15)

On September 21, 1999 a site visit was made to review the completion of the conditions of site plan approval dated 4/2/99.

It is our opinion that all conditions of the site plan approval have been satisfactorily completed and a permanent certificate of occupancy could be issued assuming Code Enforcement has no outstanding issues.

Applicant: DAVID CHASE

Date: 3/16/99

Address: Wint St Lot # 15

C-B-L: 299-D-23

CHECK-LIST AGAINST ZONING ORDINANCE

Date - ~~GB~~ New

Zone Location - R-3

Interior or corner lot -

Proposed Use/Work - contract dwelling - NO GARAGE - NO decks
→ 26' x 32'

Sewage Disposal - City NO bulkhead

Lot Street Frontage - 50' req - 137' shown

Front Yard - 25' req - 26' shown

Rear Yard - 25' req - 40' shown

Side Yard - 14' req - 30' shown AT closest point

→ Projections - NONE shown on plot plan. None approved

Width of Lot - 75' req - 137' shown
note: contractor came in to revise plans I did not add on so will need an amendment

Height - 2 story

Lot Area - 6,500^{sq} req - 11,770^{sq} shown on Appl.

Lot Coverage/ Impervious Surface - 25% - ok

Area per Family - 6,500^{sq} ok

Off-street Parking - 2 spc req - 2 shown

Loading Bays - N/A

Site Plan - minor/minor

Shoreland Zoning/ Stream Protection - N/A

Flood Plains - Free C

PLUMBING APPLICATION

297-D-025

Department of Human Sciences
Division of Health Engineering

PROPERTY ADDRESS

Town or Plantation

Portland

Street Subdivision Lot #

15 ~~Werrill St.~~ WIRT ST

PROPERTY OWNERS NAME

Last: Chase

First: David

Applicant Name:

Kris Aaskov

Mailing Address of Owner/Applicant (If Different)

304 Blackstrap Rd
Falmouth, ME 04105

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspectors to deny a Permit.

Kris Aaskov

5/10/99

Signature of Owner/Applicant

Date

PORTLAND

PERMIT # 6879

STATE COPY

Date Permit Issued:

5/11/99

\$ 48 FEE

If Double Fee Charged

209

Local Plumbing Inspector Signature

L.P.I. # 0124

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature

Date Approved

PERMIT INFORMATION

This Application is for

- 1. NEW PLUMBING
- 2. RELOCATED PLUMBING

Type of Structure To Be Served:

- 1. SINGLE FAMILY DWELLING
- 2. MODULAR OR MOBILE HOME
- 3. MULTIPLE FAMILY DWELLING
- 4. OTHER - SPECIFY _____

Plumbing To Be Installed By:

- 1. MASTER PLUMBER
- 2. OIL BURNERMAN
- 3. MFG'D. HOUSING DEALER/MECHANIC
- 4. PUBLIC UTILITY EMPLOYEE
- 5. PROPERTY OWNER

LICENSE # 02482

Hook-Up & Piping Relocation Maximum of 1 Hook-Up

HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.

OR

HOOK-UP: to an existing subsurface wastewater disposal system.

PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures.

OR

TRANSFER FEE
[\$6.00]

Number

Column 2

Type of Fixture

Number

Column 1

Type of Fixture

2 Hosebibb / Sillcock

1 Bathtub (and Shower)

Floor Drain

Shower (Separate)

Urinal

1 Sink

Drinking Fountain

2 Wash Basin

Indirect Waste

2 Water Closet (Toilet)

Water Treatment Softener, Filter, etc.

1 Clothes Washer

Grease / Oil Separator

1 Dish Washer

Dental Cuspidor

1 Garbage Disposal

Bidet

1 Laundry Tub

Other: _____

1 Water Heater

Fixtures (Subtotal)
Column 2

10 Fixtures (Subtotal)
Column 1

SEE PERMIT FEE SCHEDULE
FOR CALCULATING FEE

2 Fixtures (Subtotal)
Column 2

12 **Total Fixtures**

Fixture Fee

Transfer Fee

Hook-Up & Relocation Fee

48 **Permit Fee (Total)**

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

**Minor/Minor Site Review, Building or Use Permit Pre-Application
Detached Single Family Dwelling**

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTEIf you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.**

Location/Address of Construction <i>Lot 15 Wint St</i>		
Total Square Footage of Proposed Structure <i>1530</i>	Square Footage of Lot <i>11778</i>	
Tax Assessor's Chart, Block & Lot Number Chart# <i>299</i> Block# <i>D</i> Lot# <i>23126</i>	Owner: <i>David Chase</i>	Telephone#: <i>797 9093</i>
Lessee/Buyer's Name (If Applicable)	Owner's/Purchaser/Lessee Address: <i>50 Gray Rd Fel 04105</i>	Cost Of Work: <i>\$ 55,000</i> Fee: <i>295</i> <i>\$ 300</i>
Proposed Project Description: (Please be as specific as possible) <i>15' 30sqft Cape - full dormer</i>		
Contractor's Name, Address & Telephone <i>David Chase 50 Gray Rd Fel. 797 9093</i>		Rec'd By: <i>[Signature]</i>

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

- All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
- HVAC (Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must include the following with you application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan (Sample Attached)

A "minor/minor" site plan review is required prior to permit issuance. The Site plan must be prepared and sealed by a registered land surveyor (2 copies are required). A complete plot plan (Site Plan) includes:

- The shape and dimension of the lot, all existing buildings (if any), the proposed structure and the distance from the actual property lines. Structures include decks porches, a bow windows cantilever sections and roof overhangs, as well as, sheds, pools, garages and any other accessory structures.
- Scale and North arrow; Zoning District & Setbacks
- First Floor sill elevation (based on mean sea level datum);
- Location and dimensions of parking areas and driveways;
- Location and size of both existing utilities in the street and the proposed utilities serving the building;
- Location of areas on the site that will be used to dispose of surface water.
- Existing and proposed grade contours

4) Building Plans (Sample Attached)

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: <i>P. Chase</i>	Date: <i>3/15/99</i>
---	----------------------

Site Review Fee: \$300.00/Building Permit Fee: \$25.00 for the 1st \$1000.cost plus \$5.00 per \$1,000.00 construction cost thereafter.



**CITY OF PORTLAND, MAINE
DEVELOPMENT REVIEW APPLICATION
PLANNING DEPARTMENT PROCESSING FORM**

19990027

I. D. Number

David Chase

Applicant

50 Gray St, Falmouth, ME 04105

Applicant's Mailing Address

SAA

Consultant/Agent

797-9093

Applicant or Agent Daytime Telephone, Fax

3/15/99

Application Date

Verrill St /Wirt St Lot 15

Project Name/Description

Address of Proposed Site

299 d023

Assessor's Reference: Chart-Block-Lot

Proposed Development (check all that apply): New Building Building Addition Change Of Use Residential
 Office Retail Manufacturing Warehouse/Distribution Parking Lot Other (specify)

1530 11778
 Proposed Building square Feet or # of Units Acreage of Site Zoning

Check Review Required:

- Site Plan (major/minor)
- Flood Hazard
- Zoning Conditional Use (ZBA/PB)
- Subdivision # of lots _____
- Shoreland
- Zoning Variance
- PAD Review
- Historic Preservation
- 14-403 Streets Review
- DEP Local Certification
- Other _____

Fees Paid: Site Plan _____ Subdivision _____ Engineer Review **\$300.00** Date: 3/15/99

Inspections Approval Status:

Reviewer Marge Schmuckal

- Approved
- Approved w/Conditions see attached
- Denied
- Approval Date 3/17/99 Approval Expiration _____ Extension to _____ Additional Sheets Attached
- Condition Compliance _____ signature _____ date _____

Performance Guarantee Required* Not Required

* No building permit may be issued until a performance guarantee has been submitted as indicated below

<input type="checkbox"/> Performance Guarantee Accepted	_____	_____	_____
	date	amount	expiration date
<input type="checkbox"/> Inspection Fee Paid	_____	_____	
	date	amount	
<input type="checkbox"/> Building Permit Issued	_____		
	date		
<input type="checkbox"/> Performance Guarantee Reduced	_____	_____	_____
	date	remaining balance	signature
<input type="checkbox"/> Temporary Certificate of Occupancy	_____	<input type="checkbox"/> Conditions (See Attached)	
	date		
<input type="checkbox"/> Final Inspection	_____	_____	
	date	signature	
<input type="checkbox"/> Certificate Of Occupancy	_____		
	date		
<input type="checkbox"/> Performance Guarantee Released	_____	_____	
	date	signature	
<input type="checkbox"/> Defect Guarantee Submitted	_____	_____	_____
	submitted date	amount	expiration date
<input type="checkbox"/> Defect Guarantee Released			

**CITY OF PORTLAND, MAINE
DEVELOPMENT REVIEW APPLICATION
PLANNING DEPARTMENT PROCESSING FORM**

19990027

I. D. Number

David Chase

Applicant

50 Gray St, Falmouth, ME 04105

Applicant's Mailing Address

SAA

Consultant/Agent

797-9093

Applicant or Agent Daytime Telephone, Fax

3/15/99

Application Date

Verrill St /Wirt St Lot 15

Project Name/Description

15 Wirt St

Address of Proposed Site

299 d023

Assessor's Reference: Chart-Block-Lot

Proposed Development (check all that apply):

- New Building
 Building Addition
 Change Of Use
 Residential
 Office
 Retail
 Manufacturing
 Warehouse/Distribution
 Parking Lot
 Other (specify)

1530

11778

Proposed Building square Feet or # of Units

Acreage of Site

Zoning

Check Review Required:

- | | | | |
|--|---|--|--|
| <input checked="" type="checkbox"/> Site Plan
(major/minor) | <input type="checkbox"/> Subdivision
of lots _____ | <input type="checkbox"/> PAD Review | <input type="checkbox"/> 14-403 Streets Review |
| <input type="checkbox"/> Flood Hazard | <input type="checkbox"/> Shoreland | <input type="checkbox"/> Historic Preservation | <input type="checkbox"/> DEP Local Certification |
| <input type="checkbox"/> Zoning Conditional
Use (ZBA/PB) | <input type="checkbox"/> Zoning Variance | <input type="checkbox"/> Other _____ | |

Fees Paid: Site Plan _____ Subdivision _____ Engineer Review **\$300.00** Date: **3/15/99**

DRC Approval Status:

Reviewer **Jim Wendel**

- Approved
 Approved w/Conditions
 see attached
 Denied

Approval Date **4/2/99** Approval Expiration **4/2/00** Extension to _____ Additional Sheets Attached

Condition Compliance **Jim Wendel** **4/2/99**
 signature date

Performance Guarantee Required* Not Required

* No building permit may be issued until a performance guarantee has been submitted as indicated below

<input type="checkbox"/> Performance Guarantee Accepted	_____	_____	_____
	date	amount	expiration date
<input type="checkbox"/> Inspection Fee Paid	_____	_____	
	date	amount	
<input type="checkbox"/> Building Permit	_____		
	date		
<input type="checkbox"/> Performance Guarantee Reduced	_____	_____	_____
	date	remaining balance	signature
<input type="checkbox"/> Temporary Certificate Of Occupancy	_____	<input type="checkbox"/> Conditions (See Attached)	
	date		
<input type="checkbox"/> Final Inspection	_____	_____	
	date	signature	
<input type="checkbox"/> Certificate Of Occupancy	_____	_____	
	date	signature	
<input type="checkbox"/> Performance Guarantee Released	_____	_____	
	date	signature	
<input type="checkbox"/> Defect Guarantee Submitted	_____	_____	
	submitted date	amount	expiration date
<input type="checkbox"/> Defect Guarantee Released	_____	_____	
	date	signature	

CITY OF PORTLAND, MAINE
DEVELOPMENT REVIEW APPLICATION
PLANNING DEPARTMENT PROCESSING FORM
ADDENDUM

19990027
I. D. Number

David Chase
Applicant
50 Gray St, Falmouth, ME 04105
Applicant's Mailing Address
SAA
Consultant/Agent
797-9093
Applicant or Agent Daytime Telephone, Fax

3/15/99
Application Date
Verrill St /Wirt St Lot 15
Project Name/Description

15 Wirt St
Address of Proposed Site
299 d023
Assessor's Reference: Chart-Block-Lot

DRC Conditions of Approval

Approved Subject to Site Plan Review Addendum Conditions of Approval:

All damage to sidewalk, curb, street, or public utilities shall be repaired to City of Portland standards prior to issuance of a Certificate of Occupancy.

Two (2) City of Portland approved species and size trees must be planted on your street frontage prior to issuance of a Certificate of Occupancy.

Your new street address is now 15 Wirt Street, the number must be displayed on the street frontage of your house prior to issuance of a Certificate of Occupancy.

The Development Review Coordinator (874-8300 ext.8722) must be notified five (5) working days prior to date required for final site inspection. Please make allowances for completion of site plan requirements determined to be incomplete or defective during the inspection. This is essential as all site plan requirements must be completed and approved by the Development Review Coordinator prior to issuance of a Certificate of Occupancy. Please schedule any property closing with these requirements in mind.

Show all utility connections: water, sanitary, sewer, storm drain, electric, telephone, cable.

A sewer permit is required for you project. Please contact Carol Merritt at 874-8300, ext . 8828. The Wastewater and Drainage section of Public Works must be notified five (5) working days prior to sewer connection to schedule an inspector for your site.

As-built record information for sewer and stormwater service connections must be submitted to Public Works Engineering Section (55 Portland Street) and approved prior to issuance of a Certificate of Occupancy.

The site contractor shall establish finish grades at the foundation, bulkhead and basement windows to be in conformance with the first floor elevation (FFE) and sill elevation (SE) set by the building contractor to provide for positive drainage away from entire footprint of building.

A drainage plan shall be submitted to and approved by Development Review Coordinator showing first floor elevation (FFE), sill elevation (SE), finish street/curb elevation, lot grading, existing and proposed contours, drainage patterns and paths, drainage swales, grades at or near abutting property lines, erosion control devices and locations and outlets for drainage from the property.

The Development Review Coordinator reserves the right to require additional lot grading or other drainage improvements as necessary due to field conditions.

Eroded soil shall be contained on-site. A crushed stone construction entrance shall be located at the curb cut.

Planning Conditions of Approval

Inspections Conditions of Approval

1. Separate permits shall be required for future decks, sheds, pools and/or garage.
2. Even after you came in to revise your plans, not all projections are shown on your plot plan. If you intend to construct side and front entrances, it will be necessary to apply for an amendment to actually show those items on your plot plan as was previously requested of you. That amendment shall be applied for prior to the construction of these projections.

Fire Conditions of Approval

**CITY OF PORTLAND, MAINE
DEVELOPMENT REVIEW APPLICATION
PLANNING DEPARTMENT PROCESSING FORM
ADDENDUM**

19990027

I. D. Number

David Chase

Applicant

50 Gray St, Falmouth, ME 04105

Applicant's Mailing Address

SAA

Consultant/Agent

797-9093

Applicant or Agent Daytime Telephone, Fax

3/15/99

Application Date

Verrill St /Wirt St Lot 15

Project Name/Description

Address of Proposed Site

299 d023

Assessor's Reference: Chart-Block-Lot

DRC Conditions of Approval

Planning Conditions of Approval

Inspections Conditions of Approval

1. Separate permits shall be required for future decks, sheds, pools and/or garage.
2. Even after you came in to revise your plans, not all projections are shown on your plot plan. If you intend to construct side and front entrances, it will be necessary to apply for an amendment to actually show those items on your plot plan as was previously requested of you.
That amendment shall be applied for prior to the construction of these projections.

Fire Conditions of Approval

CITY OF PORTLAND, ME
BOCA 1996 Plan Review Record
One and Two Family Dwelling

Valuation: \$55,000.00 Plan Review # 29
 Fee: \$ 295.00 Date: 17 March

Building Location: Verrill & Mint St. CBL: 299-D-023

Building Description: Single Family Dwelling

Reviewed by: S. Hoffses

Use or Occupancy: R-3 Type of Construction: 5-B

*NR: Not Required NA: Not Applicable SR: See Report X: OK per plan

Correction List		
NO:	Description	Code Section
1.	All site plan and building Code Requirements must be completed before a Certificate of occupancy can or will be issued	111.0
2.	Foundation drains	1913.5.2
3.	Foundation anchors	2305.17
4.	Waterproofing & damp proofing	1813.0
5.	Concrete protection	1908.0
6.	Chimneys and vents	BOCA/mech/1993 Chapter 12 NFPA 201
7.	Guardrails & handrails	1021.0 1022.0
8.	Stair Construction	1014.0
9.	Sleeping room window egress	1018.6
10.	Smoke detectors	920.7.1
11.	Fastening Schedule	Table 2305.2
12.	Ventilation of spaces	BOCA/mech/1993 m-16.

REV: PSH 6-28-98

Correction List		
NO:	Description	Code Section
13	Boring, cutting and notching	2305.4.4, 2305.5.1, 2305.5.3.
14	Glass & glazing	Ch. 24

rev:PSH 6-28-98

Foundations (Chapter 18)

Wood Foundation (1808)

- ~~NA~~ Design
- ~~NA~~ Installation

Footings (1807.0)

- ~~X~~ Depth below (outside) grade 4' minimum; but below frost line except for insulated footings.
- ~~NA~~ Insulated footing provided
- ~~X~~ Soil bearing value (table 1804.3)
- ~~X~~ Footing width
- ~~X~~ Concrete footing (1810.0) .3.1, 3.2
- _____
- _____
- _____
- _____
- _____

Foundation Walls

- ~~X~~ Design (1812.1)
- ~~X~~ Minimum thickness Tables 1812.3.2.(1) & 1812.3.2 (2)
- ~~SA~~ Water proofing and damp proofing Section 1813
- ~~X~~ Sill plate (2305.17)
- ~~SA~~ Anchorage bolting in concrete (2305.17)
- ~~X~~ Columns (1912)
- ~~NA~~ Crawl space (1210.2) Ventilation
- ~~NA~~ Crawl opening size (1210.2.1)
- ~~NA~~ Access to crawl and attic space (1211.0)
- _____

Floors (Chapter 16-23)

- ~~X~~ Joists - Non sleeping area LL40PSF (Table - 1606)
- ~~X~~ Joists - Sleeping area LL30PSF (Table - 1606)
- ~~X~~ Grade
- ~~X~~ Spacing
- ~~X~~ Span
- ~~X~~ Girder 4" bearing 2305.6.1

Floors (contd.)

- ~~X~~ Bearing (1 1/2" minimum on wood or steel 3" on masonry) and lapped (3") 2305.2
- ~~SA~~ Bridging (2305.16)
- ~~SA~~ Boring and notching (2305.5.1)
- ~~SA~~ Cutting and notching (2305.3)
- ~~SA~~ Fastening table (2305.2)
- ~~NA~~ Floor trusses (AFPANDS Chapter 35)
- ~~X~~ Draft stopping (721.7)
- ~~X~~ Framing of openings (2305.11) (2305.12)
- ~~X~~ Flooring - (2304.4) 1" solid - 1/2" particle board
- ~~X~~ Concrete floors (1905) 3 1/2" 6 mil polyethylene vapor retarder

Wall Construction (Chapter 2300)

- ~~X~~ Design (1609) wind loads
- ~~X~~ Load requirements
- ~~X~~ Grade
- ~~SA~~ Fastening schedule (Table 2305.2)
- ~~X~~ Wall framing (2305.4.1)
- ~~X~~ Double top plate (2305.4.2)
- ~~X~~ Bottom plates: (2305.4.3)
- ~~SA~~ Notching and boring: (2305.4.4) studs
- ~~X~~ Non load bearing walls (2305.5)
- ~~SA~~ Notching and boring (2305.5.1)
- ~~X~~ Wind bracing (2305.7)
- ~~X~~ Wall bracing required (2305.8.1)
- ~~X~~ Stud walls (2305.8.3)
- ~~X~~ Sheathing installation (2305.8.4)
- ~~X~~ Minimum thickness of wall sheathing (Table 2305.13)
- ~~NA~~ Metal construction
- ~~NA~~ Masonry construction (Chapter 21)
- ~~X~~ Exterior wall covering (Chapter 14)
- ~~X~~ Performance requirements (1403)
- ~~X~~ Materials (1404)
- ~~NA~~ Veneers (1405)
- ~~NA~~ Interior finishes (Chapter 8)

Roof-Ceiling Construction (Chapter 23)

- ~~X~~ Roof rafters - Design (2305.15) spans
- ~~X~~ Roof decking and sheathing (2305.15.1) 5/8" boards and (2307.3) (Table 2307.3.1(2))
- ~~NA~~ Roof trusses (2313.3.1)

Roof Coverings (Chapter 15)

- ~~X~~ Approved materials (1404.1)
- ~~X~~ Performance requirement (1505)
- ~~X~~ Fire classification (1506)
- ~~X~~ Material and installation requirements (1507)
- ~~X~~ Roof structures (1510.0)
- ~~X~~ Type of covering (1507)

**Chimneys and Fireplaces
 BOCA Mechanical/1993**

- ~~X~~ Masonry (1206.0)
- ~~NA~~ Factory - built (1205.0)
- Masonry fireplaces (1404)
- Factory - built fireplace (1403)
- ~~SPX~~ NFPA 211

**Mechanical
 1993 BOCA Mechanical Code**

State Plumbing Code

Load Design Criteria

Floor live load sleeping	<u>30 PSF</u>	<u>X</u>
Floor live load non sleeping	<u>40 PSF</u>	<u>X</u>
Roof live load	<u>42 PSF</u>	<u>X</u>
Roof snow load	<u>46 PSF</u>	<u>X</u>
Seismic Zone	<u>2</u>	<u>X</u>
Weathering area	<u>S</u>	<u>X</u>
Frost line depth	<u>4' MIN</u>	<u>X</u>

Glazing (Chapter 24)

- X Labeling (2402.1)
- X Louvered window or jalousies (2402.5)
- X Human impact loads (2405.0)
- X Specific hazardous locations (2405.2)
- X Sloped glazing and skylights (2404)
- _____
- _____
- _____
- _____

Private Garages (Chapter 4)

- NA General (407)
- X Beneath rooms (407.3)
- X Attached to rooms (407.4)
- X Door sills (407.5)
- X Means of egress (407.8)
- X Floor surface (407.9)
- _____
- _____

Egress (Chapter 10)

- ~~X~~ One exit from dwelling unit (1010.2)
- ~~X~~ Sleeping room window (1010.4)
- ~~X~~ EXIT DOOR (1017.3) 32" W 80" H
- ~~NA~~ Landings (1014.3.2) stairway
- ~~NA~~ Ramp slope (1016.0)
- ~~SA~~ Stairways (1014.3) 36" W
- ~~SA~~ Treads (1014.6) 10" min.
- ~~SA~~ Riser (1014.6) 7 3/4" max.
- ~~SA~~ Solid riser (1014.6.1)
- ~~NA~~ Winders (1014.6.3)
- ~~NA~~ Spiral and Circular (1014.6.4)
- ~~SA~~ Handrails (1022.2.2.) Ht.
- ~~SA~~ Handrail grip size (1022.2.4) 1 1/4" to 2"
- ~~SA~~ Guards (1012.0) 36" min.
- _____
- _____
- _____

Smoke Detectors (920.3.2)

- ~~SA~~ Location and interconnection
- ~~SA~~ Power source

Dwelling Unit Separation
Table 602

Electrical
NFPA #