

8/21/01 - Called for final on garage. 1. No electrical permit was applied for. 2. Electrical connections made at garage lights need boxes. 3. Collar ties must be changed. 4. Need specs on I-Beam. Owner will take care of and call for RE-inspection. JR

1/23/02 Final insp. w/ K. Carroll. Checked electrical, all OK. Permit has been issued for electrical. Collar ties are OK. Ready for clo, however there shall be no habitable space above the garage. JR



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 97 Verrill St

CBL 299A A008001

Issued to Huntley Juanita C/Bridgham, Laurence

Date of Issue 02/20/2002

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 01-0632, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

New 22x24 garage

APPROVED OCCUPANCY

Use Group R-3 Type 5b
(BOCA 1999)

Limiting Conditions:

This Certificate applies to the garage portion only. No living space is approved for the area above the garage.

This certificate supersedes certificate issued

Approved:

2/28/02

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

JK