

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

MCLEOD JUANITA C & MICHAEL J MCLEOD JTS

Located at

97 VERRILL ST

PERMIT ID: 2013-01392

ISSUE DATE: 07/23/2013

CBL: 299A A008001

has permission to **build 12' x 15'3" deck off the rear of an existing 9'8" x 15'3" deck** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Single family

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Footings/Setbacks

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-01392	Date Applied For: 07/03/2013	CBL: 299A A008001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Single Family Home	Proposed Project Description: build 12' x 15'3" deck off the rear of an existing 9'8" x 15'3" deck			
<p>Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 07/09/2013</p> <p>Note: R-3 zone Ok to Issue: <input checked="" type="checkbox"/></p> <p>lot size - 11,120 sf front - N/A (59' appears to be from street) Rear 25' min. - 25' shown on revised plot plan -7/8/133892 sf - 1744 proposed Side - one story - 8' min. - 18' shown Ok lot coverage = 3892 sf - 1744 proposd - OK</p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval. 2) As discussed during the review process, the property must be clearly identified prior to pouring concrete and compliance with the required setbacks must be established. Due to the proximity of the setbacks of the proposed addition, it may be required to be located by a surveyor. 3) This permit is being approved on the basis of plans submitted including the revised plot plan received 7/9/13. Any deviations shall require a separate approval before starting that work. 				
<p>Dept: Building Status: Approved Reviewer: Tammy Munson Approval Date: 07/19/2013</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p>				