

ELECTRICAL PERMIT

City of Portland, Me.

10830 Am



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical code and the following specification:

Date 09 August 1996

LOCATION: 61 Verrill St

Permit # 14174

OWNER Keith Stiffler ADDRESS _____

299A-A-23

							TOTAL EACH FEE		
OUTLETS									
		Receptacles		Switches		Smoke Detector	65	.20	13.00
FIXTURES		(number of)							
		incandescent		fluorescent			10	.20	2.00
		fluorescent strip						.20	
SERVICES									
		Overhead				TTL AMPSTO	800		15.00
		Underground					800	100	15.00
TEMPORARY SERV.									
		Overhead				AMPS OVER	800		25.00
		Underground					800		25.00
METERS		(number of)					1	1.00	1.00
MOTORS		(number of)						2.00	
RESID/COM		Electric units						1.00	
HEATING		oil/gas units						5.00	
APPLIANCES		Ranges	1	CookTops		Wall Ovens		2.00	
		Water heaters		Fans	1	Dryers	1	2.00	
Disposals	1	Dishwasher	1	Compactors		Others (denote)	5	2.00	10.00
MISC. (number of)		Air Cond/win						3.00	
		Air Cond/cent						10.00	
		Signs						5.00	
		Pools						10.00	
		Alarms/res						5.00	
		Alarms/com						15.00	
		Heavy Duty						2.00	
		Outlets							
		Circus/Carnv						25.00	
		Alterations						5.00	
		Fire Repairs						15.00	
		E Lights						1.00	
		E Generators						20.00	
TRANSFORMER		Panels						4.00	
		0-25 Kva						5.00	
		25-200 Kva						8.00	
		Over 200 Kva						10.00	
							TOTAL AMOUNT DUE		
							MINIMUM FEE/COMMERCIAL 35.00	MINIMUM FEE 25.00	41.00

INSPECTION: Will be ready 8/13 or will call _____

CONTRACTORS NAME Ron Laughton
 ADDRESS P.O. Box 1297 Scarborough, ME 04074
 TELEPHONE 883-5858
 MASTER LICENSE No. 14174
 LIMITED LICENSE No. _____

SIGNATURE OF CONTRACTOR

ELECTRICAL INSTALLATIONS

INSPECTION: Service 8/14 by 96
Service called in 8/14/96
Closing-in 8/13/96 by [Signature]

Permit Number 14174
Location 61 Veerill St.
Owner Keith St. Miller
Date of Permit 8/9/96
Final Inspection 9/30/96
By Inspector [Signature]

PROGRESS INSPECTIONS: 8/13/96 (Closing)
8/13/96 (Service)
9/27/96 (Final)
9/30/96 (Rinse)

DATE:	REMARKS:
9/22/96	ceiling boxes illegal / ceiling lights (6)
	- box at panel, 3-way bulb nest also illegal
	- clips on conduits
	- fixtures not finished
	- conduit for cove, phone