

ELECTRICAL INSTALLATIONS—

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection 12/24/96

By Inspector [Signature]

INSPECTION: Service _____ by _____

Service called in _____

Closing-in _____ by _____

PROGRESS INSPECTIONS:

11/18/96 Closing
12/12/96 (Final)
 _____ | _____ |
 _____ | _____ |
 _____ | _____ |
 _____ | _____ |

DATE:

REMARKS:

11/18/96	- Needs to use STACK-ITS IN (STUD BAYS)
"	- no french inspection (SERVICIE)
"	- cannot use way cable for <u>KEYLESS</u>
"	- <u>fixtures !!</u>
"	- <u>low rated box !!</u>
	<u>not used</u>
	- <u>no GFCI outlet at panel</u>
	- <u>written board used for panel (back board)</u>
	<u>(not legal)</u>

(KEITH Stiffen)
 892-0875

Bulden