

COMMENTS

- 5-22-00 left message for pre-construction JB
- 5-22-00 pre construction phone call. Discussed setbacks, guard rails, handrails & spacing. Deck is within 15 1/2 to 30" height for 36" Guard. How sauna poured & fasteners in place. Setback msp 5/24 7am JB
- 5-24-00 Setback inspection to pin ok. Simpson brackets for posts, rim lagged, 19" off grade requires 36" guard, will check next week. JB
- 5-31-00 Drove by - still in progress JB
- 6-5-00 Deck completed per code. stairs are not as pictured off the end but near the house entry onto driveway JB

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____