

From: "Denise Brown" <Denise.Brown@kbr.com>
To: "Jean Fraser" <JF@portlandmaine.gov>
Date: 1/24/2013 10:51 AM
Subject: RE: Review Letter RE: FEMA Emer. Radio network, 236 Lane Ave, Portland Maine (#2012-643)
Attachments: WGAN Revised drawings 01-23-13.pdf; WGAN Site Alteration Review response to comments.pdf

Good morning Jean,

I'm sorry it has taken me so long to get this to you! We have addressed all of the comments except the first one - the letter from the property owner. We are still waiting on the response from Saga Communications but FEMA sent them a reminder on Tuesday so I'm hopeful we will have that soon. I wanted to address the other comments so we might move forward on those areas.

The 80 kW generator (located east of the existing building) has not yet been ordered but we purchase these from only three vendors so I included noise data on all three selections. The enclosures for these models have similar sound levels. The small 35 kW generator is housed within a HEMP-shielded concrete module in the main project area.

Please let me know what else you may need from me. The drawings attached are the new and revised drawings only. I did not resend the drawings which were not affected by the comments. If you would like me to send a whole new set, I can certainly do so on a CD.

Thanks for all your help on this! I really appreciate it.

Denise Brown, P.E.

KBR

63 S. Royal Street, Suite 200

Mobile, AL 36602

251-450-7920

denise.brown@kbr.com <mailto:denise.brown@kbr.com>