

# Memorandum

---

**To:** Alan Kuniholm  
**From:** Mike Nugent/Manager of Inspection Services  
**Date:** 11/17/2003  
**Re:** 352 Warren Ave. (303 G001)

---

I have conducted a partial review of the plans submitted for the above property and have the following questions/comments:

- 1) The proposed stair treads do not comply with Section 1014 of the 1999 BOCA Code.
- 2) Please indicate the proposed floor load for the stairway and storage area floor system and these submissions need to be stamped.
- 3) Is the handrail/guard rail open or closed, also provide stamped construction details.
- 4) The awning and signage are not a part of this permit, a separate permit is required.
- 5) Are there other uses abutting this use that may need to be fire separated?