



P.O. Box 788
Waterville, Maine 04903-0788

999 Forest Avenue
Portland, Maine 04103

ASBESTOS ANALYSIS

Report Date: October 27, 2016

Received Date: 10/26/2016

Administrative Offices
Phone : 207-873-7711
Fax : 207-873-7022

Customer Service
Phone : 207-878-6481
Fax : 207-878-2265

CLIENT
Robert W Rickett Jr
Abatement Professionals Corp
590 County Rd Suite 2
Westbrook ME 04092

Analysis Report of Bulk Material via
EPA Method 600/R-93/116 Polarized
Light Microscopy

| SAMPLE ID | Project Number | Project Name | Color | Non-Asbestos | | Asbestos |
|--|----------------|--------------|-------|--------------|-------------|--------------|
| | | | | Fibrous | Non-Fibrous | |
| RC09628 | 320 Warren | | Brown | 02 % | 38 % | Not Detected |
| Client ID/Desc: B1A/Floor Tile Test: PLM NOB Analyst ASM | | | | | | |
| RC09629 | 320 Warren | | Brown | 02 % | 38 % | Not Detected |
| Client ID/Desc: B1B/Floor Tile Test: PLM NOB Analyst ASM | | | | | | |
| RC09630 | 320 Warren | | Brown | -- % | 50 % | Not Detected |
| Client ID/Desc: B1C/Floor Tile Test: PLM NOB Analyst ASM | | | | | | |
| RC09631 | 320 Warren | | Green | -- % | 45 % | Not Detected |
| Client ID/Desc: B2A/Asphalt Siding Test: PLM NOB Analyst ASM | | | | | | |
| RC09632 | 320 Warren | | Green | -- % | 57 % | Not Detected |
| Client ID/Desc: B2B/Asphalt Siding Test: PLM NOB Analyst ASM | | | | | | |
| RC09633 | 320 Warren | | Green | -- % | 54 % | Not Detected |
| Client ID/Desc: B2C/Asphalt Siding Test: PLM NOB Analyst ASM | | | | | | |
| RC09634 | 320 Warren | | Brown | -- % | 50 % | Not Detected |
| Client ID/Desc: B3A/Floor Tile Test: PLM NOB Analyst ASM | | | | | | |
| RC09635 | 320 Warren | | Brown | -- % | 54 % | Not Detected |
| Client ID/Desc: B3B/Floor Tile Test: PLM NOB Analyst ASM | | | | | | |

| SAMPLE ID | Project Number | Project Name | Color | Non-Asbestos | | Asbestos |
|--|----------------|---------------|------------|--------------|---------------------|--------------|
| | | | | Fibrous | Non-Fibrous | |
| RC09636 | 320 Warren | | Brown | -- % | 61 % | Not Detected |
| Client ID/Desc: B3C/Floor Tile | | | | | | |
| | | Analyzed Date | 10/27/2016 | Test: | PLM NOB | Analyst ASM |
| RC09637 | 320 Warren | | Yellow | 02 % | 21 % | Not Detected |
| Client ID/Desc: B4A/Linoleum | | | | | | |
| | | Analyzed Date | 10/27/2016 | Test: | PLM NOB | Analyst ASM |
| RC09638 | 320 Warren | | Yellow | 02 % | 22 % | Not Detected |
| Client ID/Desc: B4B/Linoleum | | | | | | |
| | | Analyzed Date | 10/27/2016 | Test: | PLM NOB | Analyst ASM |
| RC09639 | 320 Warren | | Yellow | 03 % | 25 % | Not Detected |
| Client ID/Desc: B4C/Linoleum | | | | | | |
| | | Analyzed Date | 10/27/2016 | Test: | PLM NOB | Analyst ASM |
| RC09640 | 320 Warren | | White | -- % | 100% | Not Detected |
| Client ID/Desc: B5A/Popcorn - Spray on | | | | | | |
| | | Analyzed Date | 10/26/2016 | Test: | PLM Visual Estimate | Analyst ASM |
| RC09641 | 320 Warren | | White | -- % | 100% | Not Detected |
| Client ID/Desc: B5B/Popcorn - Spray on | | | | | | |
| | | Analyzed Date | 10/26/2016 | Test: | PLM Visual Estimate | Analyst ASM |
| RC09642 | 320 Warren | | White | -- % | 100% | Not Detected |
| Client ID/Desc: B5C/Popcorn - Spray on | | | | | | |
| | | Analyzed Date | 10/26/2016 | Test: | PLM Visual Estimate | Analyst ASM |
| RC09643 | 320 Warren | | Cream | 17 % | 83 % | Not Detected |
| Client ID/Desc: B6A/Drywall | | | | | | |
| | | Analyzed Date | 10/26/2016 | Test: | PLM Visual Estimate | Analyst ASM |
| RC09644 | 320 Warren | | Cream | 22 % | 78 % | Not Detected |
| Client ID/Desc: B6B/Drywall | | | | | | |
| | | Analyzed Date | 10/26/2016 | Test: | PLM Visual Estimate | Analyst ASM |
| RC09645 | 320 Warren | | Cream | 22 % | 78 % | Not Detected |
| Client ID/Desc: B6C/Drywall | | | | | | |
| | | Analyzed Date | 10/26/2016 | Test: | PLM Visual Estimate | Analyst ASM |
| RC09646 | 320 Warren | | White | -- % | 100% | Not Detected |
| Client ID/Desc: B7A/Joint Compound | | | | | | |
| | | Analyzed Date | 10/26/2016 | Test: | PLM Visual Estimate | Analyst ASM |

| SAMPLE ID | Project Number | Project Name | Color | Non-Asbestos | | Asbestos |
|------------------------|---------------------------|----------------------|-------------------|--------------|----------------------------|--------------------|
| | | | | Fibrous | Non-Fibrous | |
| RC09647 | 320 Warren | | White | -- % | 100% | Not Detected |
| Client ID/Desc: | B7B/Joint Compound | Analyzed Date | 10/26/2016 | Test: | PLM Visual Estimate | Analyst ASM |
| RC09648 | 320 Warren | | White | -- % | 100% | Not Detected |
| Client ID/Desc: | B7C/Joint Compound | Analyzed Date | 10/26/2016 | Test: | PLM Visual Estimate | Analyst ASM |

Should you have any questions concerning your asbestos test result(s), please feel free to call us. Thank you for using Northeast Laboratory testing services. Contact NEL for your other environmental analytical needs, including water testing for lead and arsenic or indoor air quality.

Authorized by: **Bill Sargent, Laboratory Manager**

Date: 10/27/2016

Analytical results and reports are generated by NEL at the request of and for the exclusive use of the person or entity (client) named on this report. Results, reports or copies of same will not be released by NEL to any third party without the prior express written consent from the client named in this report. This report applies only to those samples taken at the time, place and location referenced by the client. This report makes no express or implied warranty or guarantee as to the sampling methodology used by the individual performing the sampling. The client is solely responsible for the use and interpretation of these results and NEL makes no express or implied warranties as to such use or interpretation. NEL is not able to make and does not make a determination as to the environmental soundness, safety or health of a property from only the samples sent to their laboratory for analysis. Unless otherwise specified by the Client, NEL reserves the right to dispose of all samples after the testing of such samples is sufficiently completed or after a thirty-day period, whichever period is greater. NEL liability extends only to the cost of the testing. State of Maine license #LB-0082.