

DEAN & ALLYN, INC.

ALARM & DETECTION EQUIPMENT TEST REPORT

FIRE PROTECTION - SPECIAL HAZARD

PAGE 1 OF 2

32 Lewiston Road / Bldg. 1C / PO Box 709 / Gray, ME 04039
 Tel: 207/657 - 5646 Fax: 207/657 - 5647

Report To: BJ's Wholesale Club
 Street 513 Warren Ave
 City & State Portland, ME
 Phone No. 207/797-8400
 Building Location Same

Test Report No. 1
 Contract No. C1235
 Contact Sean McGee
 Date 12/14/15
 Inspector Eric Elkanich

1. Before Test Notify Proper Authorities

NAME

PHONE NO.

A. Owner or Owner's Rep. Mary - Store Mgr 797-8400
 B. Fire Dept. PFD 874-8576
 C. Central Station _____

2. Control Panel Status Before Test

A. Is the Panel connected to the Fire Dept. Master Box
 Lease Line

B. Is the Power Light On?

C. Does the Panel Indicate Normal Conditions?

D. Are all Indicating Lamp Bulbs in Operating Order?

E. Does the Trouble Light Operate?

F. Does the Silence Switch Operate?

G. Does the Panel have Active Zones? No. n/a

H. Does the Panel have Inactive Zones? No. n/a

I. Does the Panel have Battery Backup?

J. Do the Batteries Indicate they are Property Charged?

K. Have Fire Dept. and/or Lease Lines been Disconnected before Continuing Tests?

YES	N/A	NO
<input checked="" type="checkbox"/>		
<input checked="" type="checkbox"/>		
<input checked="" type="checkbox"/>		
<input checked="" type="checkbox"/>		
<input checked="" type="checkbox"/>		
	<input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/>		
		<input checked="" type="checkbox"/>

System Make & Model: Silent Knight 5808 Addressable fire alarm panel

Comments: _____

Full test performed allowing all signals to report to customers central station

3. Extinguishing Systems

A. Type of Systems n/a

B. No. of Systems n/a

C. Are Systems at Proper Pressure and Weight?

D. Do System Components Appear to be in Good External Condition?

E. Did Systems Operate Properly?

YES	N.A.	NO
	<input checked="" type="checkbox"/>	
	<input checked="" type="checkbox"/>	

Comments: _____

None Installed

by Honeywell

POINT LISTING

Point ID	Point Name	Point Type	Location
33:s031	Main Electric Room	Init:Addr:Detector:Photo	Z4
33:s032	2nd Flr Electric Rm	Init:Addr:Detector:Photo	Z4
33:s033	2nd Flr Comp Rm	Init:Addr:Detector:Photo	Z4
33:s034	Tire Inventory	Init:Addr:Detector:Photo	Z4
33:s035	Tire Inventory	Init:Addr:Detector:Photo	Z4
33:s036	Compactor Area	Init:Addr:Detector:Photo	Z4
33:s037	Tire Sales Office	Init:Addr:Detector:Photo	Z4
33:s038	Tire Install Bays	Init:Addr:Detector:Heat	Z4
33:s039	2nd Flr Transformer	Init:Addr:Detector:Photo	Z4
33:m001	Employee Break Room	Init:Addr:Switch:Manual Pull	Z1
33:m002	Bakery Area Door 505	Init:Addr:Switch:Manual Pull	Z1
33:m003	Cooler Area Door 506	Init:Addr:Switch:Manual Pull	Z1
33:m004	Compactor Door 507	Init:Addr:Switch:Manual Pull	Z1
33:m005	Freezer Area	Init:Addr:Switch:Manual Pull	Z1
33:m006	Employee Entrance	Init:Addr:Switch:Manual Pull	Z1
33:m007	Garage Bay Door	Init:Addr:Switch:Manual Pull	Z1
33:m008	Tire Sales Door	Init:Addr:Switch:Manual Pull	Z1
33:m009	Tire Area Door	Init:Addr:Switch:Manual Pull	Z1
33:m010	Sprinkler Area Door	Init:Addr:Switch:Manual Pull	Z1
33:m011	Door by Elect Panel	Init:Addr:Switch:Manual Pull	Z1
33:m012	Main Entry Door	Init:Addr:Switch:Manual Pull	Z1
33:m013	Door 501 By Main Ent	Init:Addr:Switch:Manual Pull	Z1
33:m014	Door 502 by Main Ent	Init:Addr:Switch:Manual Pull	Z1
33:m015	Door 503 Office Area	Init:Addr:Switch:Manual Pull	Z1
33:m016	1st Floor Stair Door	Init:Addr:Switch:Manual Pull	Z1
33:m017	2nd Floor Stairs	Init:Addr:Switch:Manual Pull	Z1
33:m020	Freezer Tamper Valve	Init:Addr:Switch:Tamper	Z1
33:m021	Riser # 1 Waterflow	Init:Addr:Switch:Water Flow	Z3
33:m022	Riser # 2 Waterflow	Init:Addr:Switch:Water Flow	Z3
33:m023	Riser # 3 Waterflow	Init:Addr:Switch:Water Flow	Z3
33:m024	Riser # 4 Waterflow	Init:Addr:Switch:Water Flow	Z3
33:m025	Main Tamper Building	Init:Addr:Switch:Tamper	Z2
33:m026	Main Tamper Street	Init:Addr:Switch:Tamper	Z2
33:m027	Tamper Outside # 3	Init:Addr:Switch:Tamper	Z2
33:m028	Tamper Outside # 4	Init:Addr:Switch:Tamper	Z2
33:m029	Tamper Outside # 1	Init:Addr:Switch:Tamper	Z2
33:m030	Tamper Outside # 2	Init:Addr:Switch:Tamper	Z2
33:m041	RTU # 1 Duct Smoke	Init:Addr:Switch:Supervisory	Z5
33:m042	RTU # 2 Duct Smoke	Init:Addr:Switch:Supervisory	Z5
33:m043	RTU # 3 Duct Smoke	Init:Addr:Switch:Supervisory	Z5
33:m044	RTU # 4 Duct Smoke	Init:Addr:Switch:Supervisory	Z5
33:m045	RTU # 5 Duct Smoke	Init:Addr:Switch:Supervisory	Z5
33:m046	RTU # 6 Duct Smoke	Init:Addr:Switch:Supervisory	Z5
33:m047	RTU # 7 Duct Smoke	Init:Addr:Switch:Supervisory	Z5
33:m048	RTU # 8 Duct Smoke	Init:Addr:Switch:Supervisory	Z5
34:001	NAC Booster Panel	Notif:Conv:	G1
34:002	Spare NAC Circuit #2	Notif:Conv:	G1
34:003	Spare NAC Circuit #3	Notif:Conv:	G1
34:005	Alarm Trip to FACP	Notif:Conv:Relay:	G124
34:006	Supervisory Relay	Notif:Conv:Relay:	G125